


POND PLAN



- NOTES**
- 1. Pond 1 West attenuation storage 1,650 m3. Discharge limit 6.0 l/s to the Kest tributary.
 - 2. Top water level +11.90 mAOD. Base level +10.40 mAOD. Side slopes 1 in 4.

Rev	Date	Description
C01	10/03/2025	Issued for construction
Client: Northvale County Council Designer: Arden Moss Consulting Engineers Kestrel Valley Link Road Pond 1 West General Arrangement Drawing number: KVL-ADM-310-DR-D-0310 Revision: C01 Status: FC - For construction Scale: 1:200 @ A1 Date: 10 March 2025 Drawn: SW Checked: DO Approved: PN		