



ILCO
FARMING

Authorised
Copy

**ORIGINAL
DOCUMENT**

STANDARD OPERATING PROCEDURE

PROCEDURE FOR POWER FAILURE BACKUP

Page 1 of 5

SOP No:	5-SEC-010	Effective Date:	2020-05-06
Revision No:	3	Supersedes:	2
Revise By:	2022-05-06		

LIST OF ABBREVIATIONS

AR	Authorised Representative
SOP	Standard Operating Procedure

1. OBJECTIVE:

This SOP describes the process for power failure backup control at ILCO Farming (Pty) Ltd.

2. SCOPE:

This SOP applies to all equipment and systems powered by electricity and describes how these will continue to function during a power failure.

3. RESPONSIBILITY:

AR	Authorised Representative
FM	Facility Manager

4. POLICY:

Electricity is a fundamental source of power for security monitoring and operations at the facility where medicinal cannabis is processed and warehoused and where backup power is required to keep the facility operational.

5. PROCEDURE:

- 5.1 The temperature in the general storage areas in the processing facility should not exceed 25°C.
- 5.2 The facility has a 400 KVA backup generator.
- 5.3 If Municipal power is interrupted the generator will automatically start up within a 2 second delay.
- 5.4 The fuel capacity in the generator will have 1000 litres of Diesel.
- 5.5 The generator will run for 72 hours on a 50% capacity; therefore, the AR will decide on what areas/rooms will remain operational. A risk assessment will be initiated following the SOP: 4-FPH-004 Quality Risk Management.
- 5.6 If 100% capacity is needed, the facility would run for 16 hours on backup power.

COPY NO:		
Compiler:	Authorised by:	Approved by:
CCB – Nico Kriek	Coenraad Venter	Ilse Venter