



ILCO
FARMING

Authorised
Copy

**ORIGINAL
DOCUMENT**
T

STANDARD OPERATING PROCEDURE

PROCEDURE FOR POWER FAILURE BACKUP

Page 2 of 5

SOP No:	5-SEC-010	Effective Date:	2020-05-06
Revision No:	3	Supersedes:	2
Revise By:	2022-05-06		

- 5.7 Should any of the equipment not start up where the supply of electricity commences, the FM will notify the maintenance team immediately, or notify the service provider contracted to ILCO Farming (Pty) Ltd.
- 5.8 Deviations in temperature and or humidity should be documented and investigated for risk as per the SOP: 4-FPH-002 Incident or Deviation Control.
- 5.9 The maintenance team or service provider must document the activities performed and assess the risk with the AR.

6. ATTACHMENTS:

Attachment 6.1 SOP Amendment History

Attachment 6.2 Distribution List of SOPs

COPY NO:		
Compiler:	Authorised by:	Approved by:
CCB – Nico Kriek	Coenraad Venter	Ilse Venter