



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw Jackson

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw mays

East-West Road Name

Calibration Date

8/13/2024

(mm/dd/yy)

Ramp Style **PR**

RAMP RUN 1

Pass

Fail

Running Slope 1

6.6

≤ 8.3%



>8.3%



Length 1

14.65

Cross Slope 1

1.3

≤ 2.0%



>2.0%



Detectable Warning (Y,N)

Y



N



Lip Height

1/4"



>1/4"



Gutter Flow Slope

N/A

1.1

≤ *



>*



Curb Running Slope (avg)

5.8

≤ 8.3%



>8.3%



Counter Slope (+/-) *2

6.1

≤ |5.0%|



> |5.0%|



Longest distance from corner to back of curb (see dwg on BT form)

< 5.0'



≥ 5.0'



Detectable warning extends full width of ramp throat opening

Y



N



TURN SPACE



LANDING



NONE



Pass

Fail

Width X

3.7

≥ 4.0'



< 4.0'



Length Y

5.3

≥ 4.0'*1



< 4.0'*1



Back of Ramp Obstruction (Y/N)

≥ 5.0'*1



< 5.0'*1



Slope X

≤ 2.0%



> 2.0%



Slope Y

≤ 2.0%



> 2.0%



MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1



≤ 10%



< 10%



Flare Slope 2



≤ 10%



< 10%



Clear Width (feet)

3.7

≥ 4.0'



< 4.0'



Intersection Control Type

SU

Slope of Road


1.4

Horizontal Gaps

≤ 1/2"




> 1/2"



PE Stamp (required for private development)

Comments:



PERPENDICULAR RAMP (PR)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

