



# ADA Curb Ramp New Construction Inspection Form (Perpendicular)

North-South Road Name

Project No.

Sheet No.

Intersection No.

East-West Road Name

Calibration Date

(mm/dd/yy)

o k y t - ) - )  
#

Ramp Style

## RAMP RUN 1

Pass

Fail

Running Slope 1

≤ 8.3%

>8.3%

Length 1

Cross Slope 1

≤ 2.0%

>2.0%

Detectable Warning (Y,N)

Y

N

Lip Height

1/4"

>1/4"

Gutter Flow Slope

N/A

≤ \*

>\*

Curb Running Slope (avg)

≤ 8.3%

>8.3%

Counter Slope (+/-) \*2

≤|5.0%|

>|5.0%|

Longest distance from corner to back of curb (see dwg on BT form)

< 5.0'

≥ 5.0'

Detectable warning extends full width of ramp throat opening

Y

N

TURN SPACE

LANDING

NONE

Pass

Fail

Width X

≥ 4.0'

< 4.0'

Length Y

≥ 4.0'\*1

< 4.0'\*1

Back of Ramp Obstruction (Y/N)

≥ 5.0'\*1

< 5.0'\*1

Slope X

≤2.0%

>2.0%

Slope Y

≤2.0%

>2.0%

## MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

≤ 10%

< 10%

Flare Slope 2

≤ 10%

<10%

Clear Width (feet)

≥ 4.0'

< 4.0'

Intersection Control Type

Slope of Road

Horizontal Gaps

≤1/2"

> 1/2"



PE Stamp (required for private development)

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



## PERPENDICULAR RAMP (PR)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)\*  
\* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

Comments:

Inspector's Signature

Date (mm/dd/yyyy)

Print name clearly

Certification No.

Company/Agency

## **ADA Curb Ramp Images**

Attached photos must be in .pdf format in order to be placed