



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw glencoe rd

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw commercial rd

East-West Road Name

Calibration Date

8/30/2024

(mm/dd/yy)

Ramp Style PR

RAMP RUN 1

Pass

Fail

Running Slope 1

1.8

≤ 8.3%

■

>8.3%

□

Length 1

10.4

Cross Slope 1

2.6

≤ 2.0%

□

>2.0%

■

Detectable Warning (Y,N)

Y

■

N

□

Lip Height

1/4"

□

>1/4"

□

Gutter Flow Slope

1.6

≤ *

□

>*

□

Curb Running Slope (avg)

3.14

≤ 8.3%

□

>8.3%

□

Counter Slope (+/-) *2

1.7

≤ |5.0%|

□

>|5.0%|

□

Longest distance from corner to back of curb (see dwg on BT form)

< 5.0'

■

≥ 5.0'

□

Detectable warning extends full width of ramp throat opening

Y

■

N

□

TURN SPACE

■

LANDING

□

NONE

□

Pass

Fail

Width X

7.85

≥ 4.0'

■

< 4.0'

□

Length Y

7.95

≥ 4.0'*1

■

< 4.0'*1

□

Back of Ramp Obstruction (Y/N)

≥ 5.0'*1

□

< 5.0'*1

□

Slope X

1.4

≤ 2.0%

■

>2.0%

□

Slope Y

1.4

≤ 2.0%

■

>2.0%

□

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

■

≤ 10%

■

< 10%

□

Flare Slope 2

■

≤ 10%

■

<10%

□

Clear Width (feet)

≥ 4.0'

□

< 4.0'

□

Intersection Control Type

Slope of Road

1.3


Horizontal Gaps

≤ 1/2"

□

> 1/2"

□



PE Stamp (required for private development)

Comments:

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

