



ADA Curb Ramp New Construction Inspection Form (Parallel)

NW CURTIS

North-South Road Name

23886

Project No.

Sheet No.

Intersection No.

NW PACIFIC

East-West Road Name

See https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf for more corner styles.
Use Washington County corner numbering system.

Calibration Date **7/10/2024** (mm/dd/yy)

PL

Ramp Style

*The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be \leq 5.0%, and at Stop or Yield (SY), GFS must be \leq 2.0%.

*1 If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

*2 Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



PARALLEL RAMP (PL)

PARALLEL RAMP (PL)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

RAMP RUN 1

Pass Fail

Running Slope 1

1.7 \leq 2.0% ☒ > 2.0% ☐

Cross Slope 1

1.7 \leq 2.0% ☒ > 2.0% ☐

Detectable Warning

N Y ☐ N ☒

Lip Height

\leq 1/4" ☒ > 1/4" ☐

Gutter Flow Slope

0.7 \leq * ☒ > * ☐

Curb Running Slope (avg)

☐ 7.2 \leq 8.3% ☒ > 8.3% ☐

Counter Slope (+/-)*2

5.5 \leq |5.0%| ☒ > |5.0%| ☐

Det. warning full width of ramp

Y Y ☒ N ☐

RAMP RUN 2

Pass Fail

Running Slope 2

7.5 \leq 8.3% ☒ > 8.3% ☐

Length 2

7.6

Cross Slope 2

2.3 \leq 2.0% ☐ > 2.0% ☒

RAMP RUN 3

Pass Fail

Running Slope 3

5.6 \leq 8.3% ☒ > 8.3% ☐

Length 3

7.7

Cross Slope 3

1.6 \leq 2.0% ☒ > 2.0% ☐

TURN SPACE

Pass Fail

Width X

5.0 \geq 4.0' ☒ < 4.0' ☐

Length Y

5.0 \geq 4.0'*1 ☒ < 4.0'*1 ☐

Back of Ramp Obstruction (Y/N)

\geq 5.0'*1 ☒ < 5.0'*1 ☐

Slope X (Cross Slope 1)

1.7 \leq 2.0% ☒ > 2.0% ☐

Slope Y (Running Slope 1)

1.7 \leq 2.0% ☒ > 2.0% ☐

MISCELLANEOUS

Pass Fail

Clear Width (feet)


5.0 \geq 4.0' ☐ < 4.0' ☐

Intersection Control Type

SU Slope of Rd. 1.0

Horizontal Gaps

\leq 1/2" ☒ > 1/2" ☐



PE Stamp (required for private development)

Comments:
midblock east side

Inspector's Signature **Darrell Wyant** Date (mm/dd/yy) **52638**
Print name clearly Certification No.
3J Consulting
Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

