



# ADA Curb Ramp New Construction Inspection Form (Parallel)

311th North-South Road Name      24952.54 Project No.      Sheet No.      Intersection No.      Claxter East-West Road Name

See [https://www.oregon.gov/odot/Engineering/Documents\\_RoadwayEng/ADA\\_ExhibitA.pdf](https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf) for more corner styles.  
Use Washington County corner numbering system.

Calibration Date 9/20/2024 (mm/dd/yy)


PL  
Ramp Style

\*The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be  $\leq$  Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be  $\leq 5.0\%$ , and at Stop or Yield (SY), GFS must be  $\leq 2.0\%$ .

\*1 If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

\*2 Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



PARALLEL RAMP (PL)

PARALLEL RAMP (PL)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)\*  
\* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)


RAMP RUN 1	Pass	Fail
Running Slope 1	<input type="text" value=""/> $\leq 2.0\%$ <input type="checkbox"/> $> 2.0\%$ <input type="checkbox"/>	
Cross Slope 1	<input type="text" value=""/> $\leq 2.0\%$ <input type="checkbox"/> $> 2.0\%$ <input type="checkbox"/>	
Detectable Warning	<input type="text" value="Y"/> Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	
Lip Height	<input type="text" value="1.0"/> $\leq 1/4"$ <input type="checkbox"/> $> 1/4"$ <input checked="" type="checkbox"/>	
Gutter Flow Slope	<input type="text" value="1.7"/> $\leq *$ <input checked="" type="checkbox"/> $> *$ <input type="checkbox"/>	
Curb Running Slope (avg)	<input type="checkbox"/> <input type="text" value="8.2800"/> $\leq 8.3\%$ <input type="checkbox"/> $> 8.3\%$ <input type="checkbox"/>	
Counter Slope (+/-)*2	<input type="text" value="6.6"/> $\leq  5.0\% $ <input checked="" type="checkbox"/> $>  5.0\% $ <input type="checkbox"/>	
Det. warning full width of ramp	<input type="text" value="Y"/> Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	

RAMP RUN 2	Pass	Fail
Running Slope 2	<input type="text" value=""/> $\leq 8.3\%$ <input type="checkbox"/> $> 8.3\%$ <input type="checkbox"/>	
Length 2	<input type="text" value="11.2"/>	
Cross Slope 2	<input type="text" value="2.6"/> $\leq 2.0\%$ <input type="checkbox"/> $> 2.0\%$ <input checked="" type="checkbox"/>	

RAMP RUN 3	Pass	Fail
Running Slope 3	<input type="text" value="0.6"/> $\leq 8.3\%$ <input checked="" type="checkbox"/> $> 8.3\%$ <input type="checkbox"/>	
Length 3	<input type="text" value="7.5"/>	
Cross Slope 3	<input type="text" value="1.2"/> $\leq 2.0\%$ <input checked="" type="checkbox"/> $> 2.0\%$ <input type="checkbox"/>	

TURN SPACE	Pass	Fail
Width X	<input type="text" value="4.95"/> $\geq 4.0'$ <input checked="" type="checkbox"/> $< 4.0'$ <input type="checkbox"/>	
Length Y	<input type="text" value="5.0"/> $\geq 4.0' * 1$ <input checked="" type="checkbox"/> $< 4.0' * 1$ <input type="checkbox"/>	
Back of Ramp Obstruction (Y/N)	<input type="text" value="N"/> $\geq 5.0' * 1$ <input type="checkbox"/> $< 5.0' * 1$ <input type="checkbox"/>	
Slope X (Cross Slope 1)	<input type="text" value=""/> $\leq 2.0\%$ <input type="checkbox"/> $> 2.0\%$ <input type="checkbox"/>	
Slope Y (Running Slope 1)	<input type="text" value=""/> $\leq 2.0\%$ <input type="checkbox"/> $> 2.0\%$ <input type="checkbox"/>	

MISCELLANEOUS	Pass	Fail
Clear Width (feet)	<input type="text" value="4.95"/> $\geq 4.0'$ <input type="checkbox"/> $< 4.0'$ <input type="checkbox"/>	
Intersection Control Type	<input type="text" value="SY"/> Slope of Rd. <input type="text" value="0.6"/>	
Horizontal Gaps	<input type="text" value="No"/> $\leq 1/2"$ <input checked="" type="checkbox"/> $> 1/2"$ <input type="checkbox"/>	



PE Stamp (required for private development)

Comments:  
IITD, gt2

Inspector's Signature: Darrell Wyant      Date (mm/dd/yy): 52638  
Print name clearly      Certification No.  
3J Consulting      Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

## ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

