



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

NW Ridgeview PL

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

NW North AVE

East-West Road Name

Calibration Date

10/15/2024

(mm/dd/yy)

Ramp Style **PR**

RAMP RUN 1

Pass

Fail

Running Slope 1

7.2

≤ 8.3%

☒

>8.3%

☐

Length 1

5.15

Cross Slope 1

2.1

≤ 2.0%

☐

>2.0%

☒

Detectable Warning (Y,N)

Y

Y

☒

N

☐

Lip Height

0

1/4"

☒

>1/4"

☐

Gutter Flow Slope

N/A

2.1

≤ *

☒

>*

☐

Curb Running Slope (avg)

☐

2.52

≤ 8.3%

☒

>8.3%

☐

Counter Slope (+/-) *2

2.3

≤ |5.0%|

☒

> |5.0%|

☐

Longest distance from corner to back of curb (see dwg on BT form)

0.0

< 5.0'

☒

≥ 5.0'

☐

Detectable warning extends full width of ramp throat opening

Y

Y

☒

N

☐

TURN SPACE ☒

LANDING ☐

NONE ☐

Pass

Fail

Width X

5.6

≥ 4.0'

☒

< 4.0'

☐

Length Y

4.8

≥ 4.0'*1

☒

< 4.0'*1

☐

Back of Ramp Obstruction (Y/N)

N

≥ 5.0'*1

☒

< 5.0'*1

☐

Slope X

1.3

≤ 2.0%

☒

> 2.0%

☐

Slope Y

1.5

≤ 2.0%

☒

> 2.0%

☐

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

☒

≤ 10%

☒

< 10%

☐

Flare Slope 2

☒

≤ 10%

☒

< 10%

☐

Clear Width (feet)

4.8

≥ 4.0'

☐

< 4.0'

☐

Intersection Control Type

SY

Slope of Road

1.3


Horizontal Gaps

≤ 1/2"

☒

> 1/2"

☐



PE Stamp (required for private development)

Comments:

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

52638.0

Print name clearly

Certification No.


3J Consulting

Company/Agency


Reset Entire Form

Keep Intersection, Reset Fields


WashCo ADA 01 (4-2020)




PERPENDICULAR RAMP (PR)


 Pedestrian Access Route (to measure Clear Width)

 Detectable Warning Surface

 Cross Slope (2.0% max.)

 Running Slope (8.3% max.)

 Counter Slope (5.0% max.)

 Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.

 Gutter Flow Slope (as directed)

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

