



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw 289 st

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw carver st

East-West Road Name

Calibration Date

8/6/2024

(mm/dd/yy)

Ramp Style **PR**

RAMP RUN 1

Pass

Fail

Running Slope 1

5.1

≤ 8.3%



>8.3%



Length 1

12.2

Cross Slope 1

1.1

≤ 2.0%



>2.0%



Detectable Warning (Y,N)

Y



N



Lip Height

1/4"



>1/4"



Gutter Flow Slope

N/A

0.5

≤ *



>*



Curb Running Slope (avg)

3.24

≤ 8.3%



>8.3%



Counter Slope (+/-) *2

5.1

≤ |5.0%|



> |5.0%|

Longest distance from
corner to back of curb
(see dwg on BT form)

1.8

< 5.0'



≥ 5.0'

Detectable warning
extends full width of
ramp throat opening

Y



N

TURN SPACE ☒LANDING ☐NONE ☐

Pass

Fail

Width X

5.7

≥ 4.0'



< 4.0'



Length Y

5.4

≥ 4.0'*1



< 4.0'*1



Back of Ramp Obstruction (Y/N)

≥ 5.0'*1



< 5.0'*1



Slope X

1.7

≤ 2.0%



> 2.0%



Slope Y

1.4

≤ 2.0%



> 2.0%



MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1



≤ 10%



< 10%



Flare Slope 2



≤ 10%



< 10%



Clear Width (feet)

≥ 4.0'



< 4.0'



Intersection Control Type

Slope of Road



0.7

Horizontal Gaps

≤ 1/2"



> 1/2"

PE Stamp (required for
private development)*See also Standard Drawings to assess provisions not shown:
(inlets, alignment, etc.)*

PERPENDICULAR RAMP (PR)

Pedestrian Access Route (to measure Clear Width)

Detectable Warning Surface

Cross Slope (2.0% max.)

Running Slope (8.3% max.)

Counter Slope (5.0% max.)

 Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.

Gutter Flow Slope (as directed)

Comments:

IITD not full width vertical drop back of
ramp obstruction

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

WashCo ADA 01 (4-2020)

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

