



# ADA Curb Ramp New Construction Inspection Form (Parallel)

Nw Glencoe rd.

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw pacific st.

East-West Road Name

See [https://www.oregon.gov/odot/Engineering/Documents\\_RoadwayEng/ADA\\_ExhibitA.pdf](https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf) for more corner styles.  
Use Washington County corner numbering system.

Calibration Date 10/9/2024 (mm/dd/yy)

PL

Ramp Style

\*The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be  $\leq$  Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be  $\leq$  5.0%, and at Stop or Yield (SY), GFS must be  $\leq$  2.0%.

\*1 If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

\*2 Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



PARALLEL RAMP (PL)

PARALLEL RAMP (PL)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)\*  
\* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

## RAMP RUN 1

Pass Fail

Running Slope 1

1.7  $\leq$  2.0% ☒ > 2.0% ☐

Cross Slope 1

1.7  $\leq$  2.0% ☒ > 2.0% ☐

Detectable Warning

Y Y ☒ N ☐

Lip Height

0  $\leq$  1/4" ☒ > 1/4" ☐

Gutter Flow Slope

1.2  $\leq$  \* ☒ > \* ☐

Curb Running Slope (avg)

☐ 1.6  $\leq$  8.3% ☒ > 8.3% ☐

Counter Slope (+/-)\*2

2.8  $\leq$  |5.0%| ☒ > |5.0%| ☐

Det. warning full width of ramp

Y Y ☒ N ☐

## RAMP RUN 2

Pass Fail

Running Slope 2

7.9  $\leq$  8.3% ☒ > 8.3% ☐

Length 2

11.5

Cross Slope 2

2.5  $\leq$  2.0% ☐ > 2.0% ☒

## RAMP RUN 3

Pass Fail

Running Slope 3

4.3  $\leq$  8.3% ☒ > 8.3% ☐

Length 3

5.5

Cross Slope 3

1.6  $\leq$  2.0% ☒ > 2.0% ☐

## TURN SPACE

Pass Fail

Width X

5.0  $\geq$  4.0' ☒ < 4.0' ☐

Length Y

5.0  $\geq$  4.0'\*1 ☒ < 4.0'\*1 ☐

Back of Ramp Obstruction (Y/N)

N  $\geq$  5.0'\*1 ☒ < 5.0'\*1 ☐

Slope X (Cross Slope 1)

1.7  $\leq$  2.0% ☐ > 2.0% ☐

Slope Y (Running Slope 1)

1.7  $\leq$  2.0% ☐ > 2.0% ☐

## MISCELLANEOUS

Pass Fail

Clear Width (feet)

5.0  $\geq$  4.0' ☐ < 4.0' ☐

Intersection Control Type

SY Slope of Rd. 0.3

Horizontal Gaps


No  $\leq$  1/2" ☐ > 1/2" ☐

4

Corner Position

1

Ramp Position



PE Stamp (required for private development)

Comments:

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

52638.0

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

## ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

