



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw Kaye way

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw Mary st

East-West Road Name

Calibration Date

8/6/2024

(mm/dd/yy)

Ramp Style **PR**

RAMP RUN 1

Pass

Fail

Running Slope 1

≤ 8.3%

>8.3%

Length 1

12.5

Cross Slope 1

≤ 2.0%

>2.0%

Detectable Warning (Y,N)

Y

N

Lip Height

1/4"

>1/4"

Gutter Flow Slope

N/A

1.7

≤ *

>*

Curb Running Slope (avg)

6.32

≤ 8.3%

>8.3%

Counter Slope (+/-) *2

3.2

≤ |5.0%|

> |5.0%|

Longest distance from corner to back of curb (see dwg on BT form)

< 5.0'

■

≥ 5.0'

Detectable warning extends full width of ramp throat opening

Y

■

N

TURN SPACE

■

LANDING

■

NONE

■

Pass

Fail

Width X

4.3

≥ 4.0'

■

< 4.0'

Length Y

5.3

≥ 4.0'*1

■

< 4.0'*1

Back of Ramp Obstruction (Y/N)

≥ 5.0'*1

■

< 5.0'*1

Slope X

2.0

≤ 2.0%

■

> 2.0%

Slope Y

1.8

≤ 2.0%

■

> 2.0%

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

■

■

≤ 10%

■

< 10%

Flare Slope 2

■

■

≤ 10%

■

< 10%

Clear Width (feet)

≥ 4.0'

■

< 4.0'

Intersection Control Type

Slope of Road


1.8

Horizontal Gaps

≤ 1/2"

■

> 1/2"



PE Stamp (required for private development)

Comments:

IITD

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

