



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw 292nd

North-South Road Name

23885.56

Project No.

Sheet No.

Intersection No.

Nw Keenon

East-West Road Name

Calibration Date

7/19/2024

(mm/dd/yy)


Ramp Style **PR**

* The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be \leq 5.0%, and at Stop or Yield (SY), GFS must be \leq 2.0%.

* ¹ If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

* ² Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



PERPENDICULAR RAMP (PR)

Pedestrian Access Route (to measure Clear Width)

Detectable Warning Surface

Cross Slope (2.0% max.)

Running Slope (8.3% max.)

Counter Slope (5.0% max.)

Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.

Gutter Flow Slope (as directed)

RAMP RUN 1

Running Slope 1

4.9

\leq 8.3%

☒

>8.3%

☐

Length 1

7.7

Cross Slope 1

1.8

\leq 2.0%

☒

>2.0%

☐

Detectable Warning (Y,N)

Y

☒

N

☐

Lip Height

1/4"

☒

>1/4"

☐

Gutter Flow Slope

0.2

\leq *

☒

>*

☐

Curb Running Slope (avg)

2.78

\leq 8.3%

☒

>8.3%

☐

Counter Slope (+/-) *2

2.6

\leq |5.0%|

☒

>|5.0%|

☐

Longest distance from corner to back of curb (see dwg on BT form)

1.2

< 5.0'

☒

\geq 5.0'

☐

Detectable warning extends full width of ramp throat opening

Y

☒

N

☐

TURN SPACE ☒

LANDING ☐

NONE ☐

Pass

Fail

Width X

5.6

\geq 4.0'

☒

< 4.0'

☐

Length Y

9.35

\geq 4.0'*1

☒

< 4.0'*1

☐

Back of Ramp Obstruction (Y/N)

\geq 5.0'*1

☒

< 5.0'*1

☐

Slope X

2.7

\leq 2.0%

☐

>2.0%

☒

Slope Y

\leq 2.0%

☒

>2.0%

☐

MISCELLANEOUS Traversable

Flare Slope 1

☒

\leq 10%

☒

< 10%

☐

Flare Slope 2

☒

\leq 10%

☒

< 10%

☐

Clear Width (feet)

5.6

\geq 4.0'

☐

< 4.0'

☐

Intersection Control Type

SY

Slope of Road

0.7

Horizontal Gaps

\leq 1/2"

☒

> 1/2"

☐

1
Corner
Position

2
Ramp
Position

Corner
Positions

North

Ramp
Positions

PE Stamp (required for private development)

Comments:

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

