WASHINGTON COUNTY OREGON ADA	Curb Ramp New Constru	uction Inspection Form (Para	allel)
Main	24952.54	Hillcrest	
North-South Road Name	Project No. Sheet No.	Intersection No. East-West	Road Name See https://www.oregon.gov/odot/Engineering/Documents
	Calibration Date	10/8/2024 (mm/dd/yy)	_RoadwayEng/ADA_ExhibitA.pdf for more corner styles Use Washington County corner numbering system.
PL	RAMP RUN 1	Pass Fail	3
Ramp Style	Running Slope 1	≤ 2.0% > 2.0%	Corner
*The passing value for Gutter Flow Slope (GFS)	Cross Slope 1	≤ 2.0% > 2.0%	Position 3
depends on the Intersection Control Type. At a	Detectable Warning	Y N	3
Midblock (MB), GFS must be ≤ Slope of the Road, at Signalized or Uncontrolled (SU), GFS	Lip Height	0 ≤ 1/4" ■ > 1/4"	3A -
must be ≤ 5.0%, and at Stop	Gutter Flow Slope	1.6	North
or Yield (SY), GFS must be ≤ 2.0%.	Curb Running Slope(avg)	3.02 ≤ 8.3% ■ > 8.3%>	
*1 If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.	Counter Slope (+/-)*2	6.5 ≤ 5.0% ► > 5.0%	1 Ramp Positions
*2 Clear Space area is the width of Ramp Run 1	Det. warning full width of ramp	Y Y N	Position 5
and extends 4.0 ft into the roadway.	RAMP RUN 2	Pass Fail	PE Stamp (required for
	Running Slope 2	3.2 ≤ 8.3% ■ > 8.3%	private development)
See also Standard Drawings to assess provisions not shown:	Length 2	7	
(inlets, alignment, etc.)	Cross Slope 2	2 ≤ 2.0% ■ > 2.0%	
COMMENT AND THE COMMENT AND A	RAMP RUN 3	Pass Fail	
Counter slope Counter slope	Running Slope 3	9.8 ≤ 8.3% > 8.3%	
	Length 3	7.05	
	Cross Slope 3	≤ 2.0% ■ > 2.0%	
	TURN SPACE	Pass Fail	Comments:
	Width X	4.9 ≥ 4.0'	IITD gt2.
PARALLEL RAMP (PL)	Length Y	6.0 ≥ 4.0'*1 ■ < 4.0'*1	
PARALLEL RAMP (PL)	Back of Ramp Obstruction (Y/N)	N ≥ 5.0'*1 < 5.0'*1	
Pedestrian Access Route (to measure Clear Width)	Slope X (Cross Slope 1)	2.4 ≤ 2.0% > 2.0% ■	

Slope Y (Running Slope 1)

MISCELLANEOUS

Clear Width (feet)

Horizontal Gaps

Intersection Control Type

Detectable Warning Surface

Cross Slope (2.0% max.)

Running Slope (8.3% max.) Counter Slope (5.0% max.)

Gutter Flow Slope (as directed)

Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.

4.9

SU

≤ 2.0%

≥ 4.0'

Pass

Slope of Rd. 1.2

≤ 1/2" ■ > 1/2"

> 2.0%

< 4.0'

Fail Inspector's Signature

Darrell Wyant

Print name clearly

Company/Agency

3J Consulting

Date (mm/dd/yy)

52638

Certification No.



ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed





