



ADA Curb Ramp New Construction Inspection Form (Combination)

NW Curtis

23885.56

NW Pacific

North-South Road Name

Project No.

Sheet No.

Intersection No.

East-West Road Name

Calibration Date

(mm/dd/yy)

Ramp Style **C**

* The passing value for Gutter Flow Slope (GFS) depends on the Intersection Condition Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be $\leq 5.0\%$, and at Stop or Yield (SY), GFS must be 2.0% .

* ¹ If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 feet.

* ² Clear Space area is the width of Ramp Run 1 and extends 4.0' into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)

Pass

Fail

Longest distance from detectable warning corner to back of curb (to nearest inch)


< 5.0'

$\geq 5.0'$

Detectable warning extends full width of ramp throat opening

Y

N



COMBINATION RAMP (C)

COMBINATION RAMP (C)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

RAMP RUN 1

Pass

Fail

Running Slope 1

3.1

$\leq 8.3\%$

☒

> 8.3%

☐

Length 1

5.0

Cross Slope 1

2.1

$\leq 2.0\%$

☐

> 2.0%

☒

Detectable Warning (Y/N)

N

Y

☐

N

☒

Lip Height

$\leq 1/4"$

☒

> 1/4"

☐

Gutter Flow Slope

1.9

$\leq *$

☒

> *

☐

Curb Running Slope (avg)

7.92

$\leq 8.3\%$

☒

> 8.3%

☐

Counter Slope (+/-)*²

4.9

$\leq |5.0\%|$

☐

> |5.0%|

☒

RAMP RUN 2

Pass

Fail

Running Slope 2

9.0

$\leq 8.3\%$

☐

> 8.3%

☒

Length 2

8

Cross Slope 2

3

$\leq 2.0\%$

☐

> 2.0%

☒

RAMP RUN 3

Pass

Fail

Running Slope 3

1.8

$\leq 8.3\%$

☒

> 8.3%

☐

Length 3

8.05

Cross Slope 3

1.1

$\leq 2.0\%$

☒

> 2.0%

☐

TURN SPACE

Pass

Fail

Width X

4.0

$\geq 4.0'$

☒

< 4.0'

☐

Length Y

1.9

$\geq 4.0' * 1$

☐

< 4.0' * 1

☒

Back of Ramp Obstruction (Y/N)

$\geq 5.0' * 1$

☐

< 5.0' * 1

☐

Slope X

$\leq 2.0\%$

☐

> 2.0%

☐

Slope Y

$\leq 2.0\%$

☐

> 2.0%

☐

MISCELLANEOUS

Traversable

Pass

Fail

Flare Slope 1

☒

8.4

$\leq 10\%$

☒

> 10%

☐

Flare Slope 2

☒

3.7

$\leq 10\%$

☒

> 10%

☐

Clear Width (feet)

1.9

$\geq 4.0'$

☐

< 4.0'

☐

Horizontal Gaps (Y/N)

$\leq 1/2"$

☒



1/2"

☐

Intersection Control Type

Slope of Road

2.1



Comments:

Ramp run 3-crack in walking path

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

