



ADA Curb Ramp New Construction Inspection Form (Cut Through Island)***

Glencoe

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

West union

East-West Road Name

See https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf for more corner styles.
Use Washington County corner numbering system.

Calibration Date 10/8/2024

(mm/dd/yy)

Ramp Style

CT

RAMP RUN 1

Pass

Fail

Running Slope 1

4.4 ≤ 8.3%

Pass

Fail

Cross Slope 1

1.7 ≤ *

Pass

Fail

Detectable Warning

Y Y

Pass

Fail

Lip Height

0 ≤ 1/4"

Pass

Fail

Gutter Flow Slope

2.5 ≤ *

Pass

Fail

Curb Running Slope_(avg)

N/A

3.43 ≤ 8.3%

Pass

Fail

Counter Slope (+/-) **


3.1 ≤ 5.0%

Pass

Fail

4A

Corner Position



2

Ramp Position

PE Stamp (required for private development)

TURN SPACE

Pass

NO TURN SPACE

Pass

Fail

Fail

Width X

10.0 ≥ 5.0'

Pass

Fail

Length Y

10.6 ≥ 5.0'

Pass

Fail

Slope X

1.6 ≤ 2.0%

Pass

Fail

Slope Y

0.9 ≤ 2.0%

Pass

Fail

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

Pass

Fail

Flare Slope 2

Pass

Fail

Clear Width (feet)

≥ 5.0'

Pass

Fail

Intersection Control Type

SY

Slope of Road

2.5

Cut Through Length ≥ 6 FT (Y/N)

Horizontal Gaps < 1/2" (Y/N)

Comments:

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

Print name clearly

52638.0

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

