



# ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw 313th ave

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

Nw. Brookings st

East-West Road Name

Calibration Date

10/24/2024

(mm/dd/yy)

Ramp Style **PR**

## RAMP RUN 1

Pass

Fail

Running Slope 1

7.5

≤ 8.3%

■

>8.3%

□

Length 1

4.3

Cross Slope 1

2.0

≤ 2.0%

■

>2.0%

□

Detectable Warning (Y,N)

Y

Y

■

N

□

Lip Height

0

1/4"

■

>1/4"

□

Gutter Flow Slope

1

≤ \*

■

>\*

□

Curb Running Slope (avg)

2.7

≤ 8.3%

■

>8.3%

□

Counter Slope (+/-) \*2

3

≤ |5.0%|

□

> |5.0%|

□

Longest distance from corner to back of curb (see dwg on BT form)

0.0

< 5.0'

■

≥ 5.0'

□

Detectable warning extends full width of ramp throat opening

Y

Y

■

N

□

TURN SPACE

■

LANDING

□

NONE

□

Pass

Fail

Width X

5.35

≥ 4.0'

■

< 4.0'

□

Length Y

4.85

≥ 4.0'\*1

■

< 4.0'\*1

□

Back of Ramp Obstruction (Y/N)

N

≥ 5.0'\*1

■

< 5.0'\*1

□

Slope X

1.9

≤ 2.0%

■

> 2.0%

□

Slope Y

2.2

≤ 2.0%

□

> 2.0%

■

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

■

□

≤ 10%

■

< 10%

□

Flare Slope 2

■

□

≤ 10%

■

< 10%

□

Clear Width (feet)

□

≥ 4.0'

□

< 4.0'

□

Intersection Control Type

SY

Slope of Road

0.5

Horizontal Gaps


□

≤ 1/2"

■


> 1/2"

□



PE Stamp (required for private development)

Comments:



## PERPENDICULAR RAMP (PR)

□ Pedestrian Access Route (to measure Clear Width)

□ Detectable Warning Surface

↔ Cross Slope (2.0% max.)

← Running Slope (8.3% max.)

↗ Counter Slope (5.0% max.)

↻ Turning Space (X & Y) (2.0% max. / 4' x 4' min.)\*  
\* If constrained at back of walk, min. Y length is 5'.

→ Gutter Flow Slope (as directed)

Reset Entire Form

Keep Intersection, Reset Fields

WashCo ADA 01 (4-2020)

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

## ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

