



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

NW 309th Ave

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

NW Timeric Dr

East-West Road Name

Calibration Date

11/6/2024

(mm/dd/yy)

Ramp Style


PR

* The passing value for Gutter Flow Slope (GFS) depends on the Intersection Control Type. At a Midblock (MB), GFS must be \leq Slope of the Road, at Signalized or Uncontrolled (SU), GFS must be \leq 5.0%, and at Stop or Yield (SY), GFS must be \leq 2.0%.

* ¹ If Back of Ramp Obstruction is Yes, turn space length Y must be minimum 5.0 ft.

* ² Clear Space area is the width of Ramp Run 1 and extends 4.0 ft into the roadway.

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)




PERPENDICULAR RAMP (PR)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)*
- * If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

RAMP RUN 1		Pass	Fail
Running Slope 1	6.7	$\leq 8.3\%$	$> 8.3\%$
Length 1	10.15		
Cross Slope 1	1.2	$\leq 2.0\%$	$> 2.0\%$
Detectable Warning (Y,N)	Y	Y	N
Lip Height	0	1/4"	$> 1/4"$
Gutter Flow Slope	1.9	$\leq *$	$> *$
Curb Running Slope (avg)	2.19	$\leq 8.3\%$	$> 8.3\%$
Counter Slope (+/-) *2	2.8	$\leq 5.0\% $	$> 5.0\% $
Longest distance from corner to back of curb (see dwg on BT form)		$< 5.0'$	$\geq 5.0'$
Detectable warning extends full width of ramp throat opening	Y	Y	N

TURN SPACE	LANDING	NONE	Pass	Fail
Width X	9.15	$\geq 4.0'$	$< 4.0'$	
Length Y	5.3	$\geq 4.0' * 1$	$< 4.0' * 1$	
Back of Ramp Obstruction (Y/N)	N	$\geq 5.0' * 1$	$< 5.0' * 1$	
Slope X	1	$\leq 2.0\%$	$> 2.0\%$	
Slope Y	0.9	$\leq 2.0\%$	$> 2.0\%$	

MISCELLANEOUS		Traversable	Pass	Fail
Flare Slope 1		$\leq 10\%$	$< 10\%$	
Flare Slope 2		$\leq 10\%$	$< 10\%$	
Clear Width (feet)	5.3	$\geq 4.0'$	$< 4.0'$	
Intersection Control Type	SY	Slope of Road	1.4	
Horizontal Gaps		$\leq 1/2"$	$> 1/2"$	



PE Stamp (required for private development)

Comments:

nan

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

