

ADA Curb Ramp New Construction Inspection Form (Cut Through Island)***

Glencoe

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

West union

East-West Road Name

See https://www.oregon.gov/odot/Engineering/Documents_RoadwayEng/ADA_ExhibitA.pdf for more corner styles.
Use Washington County corner numbering system.

Calibration Date

nan

(mm/dd/yy)

Ramp Style

CT

RAMP RUN 1

Pass

Fail

Running Slope 1

2.7 ≤ 8.3%

■

> 8.3%

□

Cross Slope 1

2.2 ≤ *

□

> *

■

Detectable Warning

Y Y

■

N

□

Lip Height

0 ≤ 1/4"

□

> 1/4"

□

Gutter Flow Slope

2.5 ≤ *

□

> *

■

Curb Running Slope_(avg)

N/A

1.08 ≤ 8.3%

■

> 8.3%

□

Counter Slope (+/-) **

2.9 ≤ |5.0%|


■

> |5.0%|

□

4A

Corner Position



1

Ramp Position

PE Stamp (required for private development)

TURN SPACE

■

NO TURN SPACE

□

Pass

Fail

Width X

10.0 ≥ 5.0'

■

< 5.0'

□

Length Y

10.6 ≥ 5.0'

■

< 5.0'

□

Slope X

1.6 ≤ 2.0%

■

> 2.0%

□

Slope Y

0.9 ≤ 2.0%

■

> 2.0%

□

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

■

≤ 10%

■

> 10%

□

Flare Slope 2

■

≤ 10%

■

> 10%

□

Clear Width (feet)

10.0 ≥ 5.0'

□

< 5.0'

□

Intersection Control Type

SY

Slope of Road

2.5

Cut Through Length ≥ 6 FT (Y/N)

□

Horizontal Gaps < 1/2" (Y/N)

□

Inspector's Signature

Date (mm/dd/yy)

Darrell Wyant

52638.0

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

