



# ADA Curb Ramp New Construction Inspection Form (Perpendicular)

Nw 291 ave

North-South Road Name

23885.56

Project No.

Sheet No.

Intersection No.

Nw carver st

East-West Road Name

Calibration Date

7/23/2024

(mm/dd/yy)

Ramp Style **PR**

## RAMP RUN 1

Pass

Fail

Running Slope 1

≤ 8.3% ☐ >8.3% ☒

Length 1

13.9

Cross Slope 1

≤ 2.0% ☐ >2.0% ☒

Detectable Warning (Y,N)

Y ☐ Y ☒ N ☐

Lip Height

0 ☐ 1/4" ☒ >1/4" ☐

Gutter Flow Slope

N/A 2.0 ☐ ≤ \* ☒ >\* ☐

Curb Running Slope (avg)

☐ 0.86 ☐ ≤ 8.3% ☒ >8.3% ☐

Counter Slope (+/-) \*2

1.9 ☐ ≤ |5.0%| ☒ >|5.0%| ☐

Longest distance from corner to back of curb (see dwg on BT form)

1.35 ☐ < 5.0' ☒ ≥ 5.0' ☐

Detectable warning extends full width of ramp throat opening

Y ☐ Y ☒ N ☐

TURN SPACE ☒

LANDING ☐

NONE ☐

Pass

Fail

Width X

4.4 ☐ ≥ 4.0' ☒ < 4.0' ☐

Length Y

5 ☐ ≥ 4.0'\*1 ☒ < 4.0'\*1 ☐

Back of Ramp Obstruction (Y/N)

N ☐ ≥ 5.0'\*1 ☒ < 5.0'\*1 ☐

Slope X

3.1 ☐ ≤ 2.0% ☐ >2.0% ☒

Slope Y

☐ ≤ 2.0% ☐ >2.0% ☒

## MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

☒ ☐ ≤ 10% ☒ < 10% ☐

Flare Slope 2

☒ ☐ ≤ 10% ☒ < 10% ☐

Clear Width (feet)


☐ ≥ 4.0' ☐ < 4.0' ☐

Intersection Control Type

SY ☐ Slope of Road ☐


Horizontal Gaps

☐ ≤ 1/2" ☒ > 1/2" ☐



PE Stamp (required for private development)

See also Standard Drawings to assess provisions not shown: (inlets, alignment, etc.)



## PERPENDICULAR RAMP (PR)

- Pedestrian Access Route (to measure Clear Width)
- Detectable Warning Surface
- Cross Slope (2.0% max.)
- Running Slope (8.3% max.)
- Counter Slope (5.0% max.)
- Turning Space (X & Y) (2.0% max. / 4' x 4' min.)\*
- \* If constrained at back of walk, min. Y length is 5'.
- Gutter Flow Slope (as directed)

Comments:

Rr1 icrr

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

## ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

