



ADA Curb Ramp New Construction Inspection Form (Perpendicular)

NW 290th

North-South Road Name

24952.54

Project No.

Sheet No.

Intersection No.

NW King

East-West Road Name

Calibration Date

7/30/2024

(mm/dd/yy)

Ramp Style PR

RAMP RUN 1

Pass

Fail

Running Slope 1

≤ 8.3%

>8.3%

Length 1

Cross Slope 1

13.55

≤ 2.0%

>2.0%

Detectable Warning (Y,N)

Y

Y

N

Lip Height

1/4"

>1/4"

Gutter Flow Slope

1.8

≤ \*

>\*

Curb Running Slope (avg)

2.62

≤ 8.3%

>8.3%

Counter Slope (+/-) \*2

4.4

≤ |5.0%|

> |5.0%|

Longest distance from corner to back of curb (see dwg on BT form)

< 5.0'

≥ 5.0'

Detectable warning extends full width of ramp throat opening

Y

Y

N

TURN SPACE

■

LANDING

□

NONE

□

Pass

Fail

Width X

≥ 4.0'

< 4.0'

Length Y

≥ 4.0'\*1

< 4.0'\*1

Back of Ramp Obstruction (Y/N)

Y

≥ 5.0'\*1

< 5.0'\*1

Slope X

≤ 2.0%

> 2.0%

Slope Y

≤ 2.0%

> 2.0%

MISCELLANEOUS Traversable

Pass

Fail

Flare Slope 1

≤ 10%

< 10%

Flare Slope 2

≤ 10%

< 10%

Clear Width (feet)

≥ 4.0'

< 4.0'

Intersection Control Type

SY

Slope of Road

2.2

Horizontal Gaps

≤ 1/2"

> 1/2"

1

Corner Position

Corner Positions

North

Ramp Positions

1

Ramp Position

PE Stamp (required for private development)

Comments:

RR1 ICRR

Inspector's Signature

Date (mm/dd/yyyy)

Darrell Wyant

52638

Print name clearly

Certification No.

3J Consulting

Company/Agency

Reset Entire Form

Keep Intersection, Reset Fields

## ADA Curb Ramp Images

Attached photos must be in .pdf format in order to be placed

