

iEP SkySAFE 2.0

Aviation Safety Assessment Report

Application Reference: SKY-2025-00847

Application reference	SKY-2025-00847
IFC filename	proposal_sky2025_00847_corenet.ifc
Report generated	2026-05-19 07:51 UTC
Pipeline version	0.1.0

STAGE 1 -- IFC INGESTION & VALIDATION

PASS

- PASS** File located on SFTP landing directory
- PASS** IFC schema validated: IFC4 / IFC+SG v1.0
- PASS** Filename: proposal_sky2025_00847_corenet.ifc

STAGE 2 -- EXTERIOR SHELL EXTRACTION

PASS

Status	OK
Exterior elements extracted	312
Mesh vertices	28,450
Mesh triangles	54,918

STAGE 3 -- HEIGHT ANALYSIS

COMPLETE

Site elevation (IfcSite.RefElevation)	3.2 m (local datum)
Lowest point -- ground slab soffit	0.0 m
Highest point -- roof apex (local)	98.35 m
Building height	98.35 m
Peak height above mean sea level (AMSL)	101.55 m AMSL -- used for all aviation assessments

STAGE 4 -- GROSS FLOOR AREA (GFA)

Proposed GFA	45,230.0 m ²
--------------	-------------------------

STAGE 4b -- FACADE MATERIAL SURVEY

Unique material types identified: **3**

Material	Elements
Aluminium Panel Cladding	67
Reinforced Concrete	148
Structural Glass	62

STAGE 5 -- COMPOSITE HEIGHT TEMPLATE (CHT) INTERSECTION

**PENETRATION
DETECTED**

Max permitted height (CHT)	88.85 m AMSL
Building peak height	101.55 m AMSL
Penetration depth	12.7 m

Penetrated zones:

Zone	Permitted (m AMSL)	Building (m AMSL)	Excess (m)
CHT Zone A	88.85	101.55	12.7

Action required: CHT penetration triggers mandatory ADP officer review. CAAS must assess whether a height reduction, LOC conditions, or a formal aeronautical study is required before a Letter of Consent can be issued.

STAGE 6 -- OLS (OBSTACLE LIMITATION SURFACES) INTERSECTION

1 surface(s) penetrated

Penetrated surfaces:

Surface	Runway	OLS Height (m AMSL)	Building (m AMSL)	Depth (m)
Transitional Surface	RWY 02L/20R	94.13	101.55	7.42

Surfaces clear:

- PASS Approach Surface
- PASS Conical Surface

Note: OLS penetration must be declared in the LOC application and assessed by CAAS aerodromes engineers.

STAGE 7 -- ILS TECHNICAL TEMPLATE IMPACT

1 template(s) breached

Breached templates:

Template	System	Runway	Ceiling (m AMSL)	Building (m AMSL)	Excess (m)
ILS-WSSS-02L-L OC	Localiser	RWY 02L	85.0	101.55	16.55

Templates clear:

- PASS ILS-WSSS-20R-LOC

Action required: ILS template breach requires an RF propagation study by the CAAS ILS team before the LOC application can progress.

ASSESSMENT SUMMARY		
Check	Result	Detail
IFC Ingestion & Validation	PASS	proposal_sky2025_00847_corenet.ifc
Exterior Shell Extraction	PASS	312 elements, 54,918 triangles
Height Analysis	COMPLETE	98.35 m building height, 101.55 m AMSL peak
Gross Floor Area	PENDING	45,230.0 m²
Composite Height Template (CHT)	FAIL	Penetration: 12.7 m
OLS Intersection	FAIL	1 surface(s) penetrated
ILS Technical Template	FAIL	1 template(s) breached