

CP	PD	Notes
OSDP: INFO : CP : CP setup complete	OSDP: INFO : PD[0]: PD : PD setup complete	This is 1.4.0, with SCBK
OSDP: INFO : PD[0]: CP : SC Active	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: INFO : PD[0]: PD : SC Active	
OSDP: INFO : CP : CP setup complete	OSDP: WARN : PD[0]: PD : SCBK not provided. PD is in INSTALL_MODE	This is 1.4.0, INSTALL_MODE
OSDP: ERROR: PD[0]: CP : Failed to verify PD cryptogram	OSDP: INFO : PD[0]: PD : PD setup complete	
OSDP: WARN : PD[0]: CP : SC Failed. Retry with SCBK-D	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
OSDP: WARN : PD[0]: CP : SC Active with SCBK-D. Set SCBK	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
OSDP: INFO : PD[0]: CP : SCBK set; restarting SC to verify new SCBK	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
OSDP: INFO : PD[0]: CP : SC Active	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: WARN : PD[0]: PD : SC Active with SCBK-D	
	CP: CMD_ID: 5 OSDP: DEBUG: PD[0]: PD : CMD: 75 REPLY: 40	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: INFO : PD[0]: PD : SC Active	

CP	PD	Notes
OSDP: INFO : CP : CP setup complete	OSDP: INFO : PD[0]: PD : PD setup complete	This is 1.5.0, with SCBK from 1.4.0
OSDP: INFO : PD[0]: CP : SC Active	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: INFO : PD[0]: PD : SC Active	
OSDP: INFO : CP : CP setup complete	OSDP: WARN : PD[0]: PD : SCBK not provided. PD is in INSTALL_MODE	This is 1.5.0, INSTALL_MODE
OSDP: ERROR: PD[0]: CP : Failed to verify PD cryptogram	OSDP: INFO : PD[0]: PD : PD setup complete	
OSDP: WARN : PD[0]: CP : SC Failed. Retry with SCBK-D	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
OSDP: WARN : PD[0]: CP : SC Active with SCBK-D. Set SCBK	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
OSDP: ERROR: PD[0]: CP : Response timeout for CMD(75)	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
OSDP: ERROR: PD[0]: CP : Failed to verify PD cryptogram	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
OSDP: WARN : PD[0]: CP : SC Failed. Retry with SCBK-D	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
OSDP: WARN : PD[0]: CP : SC Active with SCBK-D. Set SCBK	OSDP: WARN : PD[0]: PD : SC Active with SCBK-D	
OSDP: ERROR: PD[0]: CP : Response timeout for CMD(75)	OSDP: ERROR: PD[0]: PHY: Invalid SOM 0xb6	
OSDP: ERROR: PD[0]: CP : Failed to verify PD cryptogram	OSDP: ERROR: PD[0]: PD : CMD receive error/timeout - err:-1	
OSDP: WARN : PD[0]: CP : SC Failed. Retry with SCBK-D	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
OSDP: WARN : PD[0]: CP : SC Active with SCBK-D. Set SCBK	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
OSDP: ERROR: PD[0]: CP : Response timeout for CMD(75)	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: WARN : PD[0]: PD : SC Active with SCBK-D	
	OSDP: ERROR: PD[0]: PHY: Invalid SOM 0x70	
	OSDP: ERROR: PD[0]: PD : CMD receive error/timeout - err:-1	
	OSDP: DEBUG: PD[0]: PD : CMD: 61 REPLY: 45	
	OSDP: DEBUG: PD[0]: PD : CMD: 62 REPLY: 46	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 76 REPLY: 76	
	OSDP: DEBUG: PD[0]: PD : CMD: 77 REPLY: 78	
	OSDP: WARN : PD[0]: PD : SC Active with SCBK-D	
	OSDP: ERROR: PD[0]: PHY: Invalid SOM 0xa3	
	OSDP: ERROR: PD[0]: PD : CMD receive error/timeout - err:-1	