



Certificate of Conformity

LOVAG-Certificate No.: IT16.103 Page 1 of 2

Apparatus: Low- voltage busbar trunking system 1000V (Ue) - $4000A(I_{nA}) - 50Hz(f) - 1000V(U_i) - 4kV(U_{imp}) - 120kA(I_{cw}) - 264kA(I_{pk})$ - IP55

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate



Designation Type:

HP 4000A

Manufacturer: DTM ELEKTROTEKNIK SAN TIC A.S. CATALMESE MAH SULTANSUYU CAD 129 ALEMDAG CEKMEKOY -ISTANBUL (Turkey)

Applicant: DTM ELEKTROTEKNIK SAN TIC A.S.- ISTANBUL (Turkey)

Verified by: VEIKI-VNL BUDAPEST (Hungary)

The apparatus, constructed in accordance with the description mentioned in the Reports listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 60439-2 (2005-10).

The results of the tests carried out fulfil the requirements of the relevant parts of IEC 61439-6 (2012-05), according to sub. 10.1 of IEC 61439-1 (2009-01).

The results are shown in the Reports in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated in the following.



Mutual Recognition Agreements

Responsible Certification Body: ACAE Via Tito Livio, 5'+ 24123 - BERGAMO (Italy)

> Authorized Signature: Virginio Scarioni Date: 2016.10.31

MOD 007 pag 1 Revisione