

Intelligent Function Module
Start I/O:0000 QD77MS4 Simple Motion Module
Input Axis Parameter

09-07-2026

Item	Axis #1	Axis #2	Axis #3	Axis #4
Command Generation Axis				
Pr.340:Valid Setting	0:Invalid	0:Invalid	0:Invalid	0:Invalid
Basic parameters 1				
Pr.1:Unit setting	3:pulse	3:pulse	3:pulse	3:pulse
Basic parameters 2				
Pr.8:Speed limit value	200000 pulse/s	200000 pulse/s	200000 pulse/s	200000 pulse/s
Pr.9:Acceleration time 0	1000 ms	1000 ms	1000 ms	1000 ms
Pr.10:Deceleration time 0	1000 ms	1000 ms	1000 ms	1000 ms
Pr.346:Length per Cycle	0 pulse	0 pulse	0 pulse	0 pulse
Detailed parameters 1				
Detailed parameters 2				
Servo input axis				
Pr.300:Servo input axis type	0:Invalid	0:Invalid	0:Invalid	0:Invalid
Detail setting				
Synchronous encoder axis				
Synchronous encoder axis setting				
Pr.320:Type	0:Invalid	0:Invalid	0:Invalid	0:Invalid
Pr.320:Axis No. of connected servo amplifier	0	0	0	0
Pr.329:Resolution of synchronous encoder via CPU	0	0	0	0
Unit setting (Position)				
Pr.321:Unit	3:pulse	3:pulse	3:pulse	3:pulse
Pr.321:Number of decimal places	0	0	0	0
Unit setting (Speed)				
Pr.321:Unit	0:s	0:s	0:s	0:s
Pr.321:Number of decimal places	0	0	0	0
Unit conversion				
Pr.322:Numerator	1 pulse	1 pulse	1 pulse	1 pulse
Pr.323:Denominator	1 pulse	1 pulse	1 pulse	1 pulse
Pr.324:Length per cycle	4000 pulse	4000 pulse	4000 pulse	4000 pulse
Detail setting				