

PLC Parameter

Data Name : PLC System

PLC System

[Timer Limit Setting]

Low Speed	100	ms
High-Speed	10.00	ms

[RUN-PAUSE Contacts]

RUN	X
PAUSE	X

[Latch Data Backup Function]

Device Name	-	-
-------------	---	---

Backup all files in standard RAM

[Remote Reset]

Not allowed

[Output Mode at STOP to RUN]

Previous State

[Floating Point Arithmetic Processing]

-

[Common Pointer No.]

P	After
---	-------

[Points Occupied by Empty Slot]

16	Points
----	--------

[System Interrupt Settings]

Interrupt Counter Start No.	-
I28 Fixed Scan Interval	100.0 ms
I29 Fixed Scan Interval	40.0 ms
I30 Fixed Scan Interval	20.0 ms
I31 Fixed Scan Interval	10.0 ms

[Interrupt Program / Fixed Scan Program Setting]

High-Speed Execution is not valid

[Module Synchronization]

Synchronize intelligent module's pulse up

[A-PLC Compatibility Setting]

Use of special relay / special register from SM/SD 1000 is not valid

[Service Processing Setting]

Execute the process as the scan time proceed 10 %

[PLC Module Change Setting]

No setting

[Built-in CC-Link Setting]

-

PLC Parameter
Data Name : PLC File
PLC File

[File Register]

Use the following file

Corresponding Memory Standard RAM (Drive 3)

File Name TAPING

Capacity 40 K Points

-

[Comment File Used in a Command]

Not Used

[Device Initial Value]

Not Used

[File for Local Device]

Not Used

[File used for SP.DEVST/S.DEVLD Instruction]

Not Used

PLC Parameter
Data Name : PLC RAS
PLC RAS

[WDT(Watchdog Timer)Setting]

WDT Setting	200	ms
Initial Execution Monitoring Time		ms
Low Speed Execution Monitoring Time	-	ms

[Error Check]

Battery Check	Valid
Fuse Blown Check	Valid
I/O Module Verify	Valid
Check Device Range at Indexing	Valid
Diagnose Redundant Power Supply System	Valid

[Operating Mode When There is an Error]

Computation Error	Stop
Expanded Command Error	Stop
Fuse Blown	Stop
Module Verify Error	Stop
Intelligent Module Program Execution Error	Stop
File Access Error	Stop
Memory Card Operation Error	Stop
External Power Supply OFF	Stop

[Operation History]

Not save operation history of CPU module

[Constant Scanning]

ms

[Error history]

-		
Target Memory	-	
File Name	-	
History No.	-	Item

[Low Speed Program Execution Time]

-	ms
---	----

[Module Error History Collection (Intelligent Function Module)]

Collection of intelligent function module error histories is val

Target Memory	System Memory
History No.	- Item
Collection No.	1 Items/Scan

PLC Parameter
Data Name : Boot File
Boot File

7/8/2026

[Boot Option]

Clear Program Memory is not valid.

High-Speed Monitor Area from Other Statio - K Steps

Online Change Area of Multiple Blocks - K Steps

-

PLC Parameter
Data Name : Program
Program

7/8/2026

[Program]

	Program Name	Execute Type	Fixed Scan Interval	In Unit	File Usability Setting			
					File Register	Device Initial Value	Comment	Local Device
1	SERVO	Scan			Use PLC File Setting	Use PLC File Setting	Use PLC File Setting	Use PLC File Setting
2	AUTO	Scan			Use PLC File Setting	Use PLC File Setting	Use PLC File Setting	Use PLC File Setting
3	MANUAL	Scan			Use PLC File Setting	Use PLC File Setting	Use PLC File Setting	Use PLC File Setting
4	OUTPUT	Scan			Use PLC File Setting	Use PLC File Setting	Use PLC File Setting	Use PLC File Setting
5	HOME	Scan			Use PLC File Setting	Use PLC File Setting	Use PLC File Setting	Use PLC File Setting

PLC Parameter
Data Name : SFC
SFC

7/8/2026

[SFC Program Start Mode]
Initial Start

[Start Conditions]
Autostart Block 0

[Output Mode When the Block is Stopped]
Turn OFF

PLC Parameter
Data Name : Device
Device

7/8/2026

[Device]

	Sym.	Dig.	Device Points	Latch (1) Start	Latch (1) End	Latch (2) Start	Latch (2) End	Local Device Start	Local Device End	Write Protection Start	Write Protection End
Input Relay	X	16	8K								
Output Relay	Y	16	8K								
Internal Relay	M	10	9K								
Latch Relay	L	10	8K								
Link Relay	B	16	8K								
Annunciator	F	10	2K								
Link Special	SB	16	2K								
Edge Relay	V	10	2K								
Step Relay	S	10	8K								
Timer	T	10	2K								
Retentive Timer	ST	10	0K								
Counter	C	10	1K	0	100						
Data Register	D	10	13K	50	2500						
Link Register	W	16	8K								
Link Special	SW	16	2K								
Index	Z	10	20								
Device Total		29.9	K Words								
Word Device		26.0	K Words								
Bit Device		45.0	K Bits								

PLC Parameter
Data Name : Device
Device

7/8/2026

[File Register Extended Setting]

Capacity 40 K Points

	Sym.	Dig.	Device Points	Latch (1) Start	Latch (1) End	Latch (2) Start	Latch (2) End	Device No. Start	Device No. End	Write Protection Start	Write Protection End
File Register	ZR(R)	10	40K			0	40959	ZR0	ZR40959		
Extended Data	D	10	0K								
Extended Link	W	16	0K								

PLC Parameter
Data Name : Device
Device

7/8/2026

[Indexing Setting for Device]
32Bit Indexing Use ZZ device

[Latch Interval Setting]
Per Scan

[Pointer Extended Setting for Automatic-Assign Device]

-

[Base Setting]

	Base Model Name	Power Model Name	Extension Cable	Slots
Main				5
Ext.Base1				
Ext.Base2				
Ext.Base3				
Ext.Base4				
Ext.Base5				
Ext.Base6				
Ext.Base7				

PLC Parameter
 Data Name : I/O Assignment
 I/O Assignment

7/8/2026

[I/O Assignment]

Main

	PLC	0	1	2	3	4
Power Supply	PLC	Intelligent	Input	Output	Input	Intelligent
	-	32Points	32Points	32Points	16Points	32Points
		QD77MS4			QX40	QJ71E71-100
Start XY	-	0000				
Error Time	-	Clear	-	Clear	-	Clear
Output Mode						
PLC	-	Stop	-	-	-	Stop
Operation Mode at H/W Error						
I/O Response Time	-	-	10ms	-	10ms	-
Control PLC	-	-	-	-	-	-
Switch Setting	1	-		-	-	-
	2	-		-	-	-
	3	-		-	-	-
	4	-		-	-	-
	5	-		-	-	-

PLC Parameter

7/8/2026

Data Name : Built-in Ethernet Port Setting

Built-in Ethernet Port Setting

IP Address 192.168.3.39 (C0.A8.03.27)

Subnet Mask Pattern - (-)

Default Router IP Address - (-)

Communication Data Code Binary Code

Enable not Online Change

Enable direct connection to MELSOFT

Do respond to search for CPU (Built-in Ethernet port) on network

IP packet transfer setting Not to use IP packet relay function

PLC Parameter
Data Name : Built-in Ethernet Port Setting
Built-in Ethernet Port Setting

7/8/2026

[Built-in Ethernet Port Open Setting]

	Protocol	Open System	TCP Connection	Host Station Port No.	Destination IP Address	Destination Port No.	Start Device to Store Predefined Protocol Operation Status
1	UDP	MELSOFT Connection					
2	TCP	MELSOFT Connection					
3	TCP	MELSOFT Connection					
4	TCP	MELSOFT Connection					
5	TCP	MELSOFT Connection					
6	TCP	MELSOFT Connection					
7	TCP	MELSOFT Connection					
8	TCP	MELSOFT Connection					
9	TCP	MELSOFT Connection					
10	TCP	MELSOFT Connection					
11	TCP	MELSOFT Connection					
12	TCP	MELSOFT Connection					
13	TCP	MELSOFT Connection					
14	TCP	MELSOFT Connection					
15	TCP	MELSOFT Connection					
16	TCP	MELSOFT Connection					

PLC Parameter
Data Name : Built-in Ethernet Port Setting
Built-in Ethernet Port Setting

[Built-in Ethernet Port FTP Parameter Setting]

FTP	Not Used
Login Name	MELSEC
Password	Setting
Command Input Monitoring Timer	1800 X 500ms

PLC Parameter
Data Name : Built-in Ethernet Port Setting
Built-in Ethernet Port Setting

7/8/2026

[Built-in Ethernet Port Time Setting]
SNTP Function Setting Not Used
SNTP Server IP Address- (-)
Time Zone (GMT+9:00)
Execute not time setting at turn ON/reset
 On-error ActionContinue
Execution Time 12:00

PLC Parameter
Data Name : Acknowledge XY Assignment
Acknowledge XY Assignment

7/8/2026

[Acknowledge XY Assignment]

XY No.	Type		Slot	Module Type	Points	Model Name	Duplication
	Network	I/O Assignment					
0000		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0010		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0020		I/O Assignment	1(0- 1)	Input	32 Points		
0030		I/O Assignment	1(0- 1)	Input	32 Points		
0040		I/O Assignment	2(0- 2)	Output	32 Points		
0050		I/O Assignment	2(0- 2)	Output	32 Points		
0060		I/O Assignment	3(0- 3)	Input	16 Points	QX40	
0070		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	
0080		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	