

Network Parameter

7/8/2026

Data Name : Ethernet/CC IE/MELSECNET
Ethernet/CC IE/MELSECNET

[Ethernet/CC IE/MELSECNET]

Valid Module During Other Station Access: 1

Interlink Transmission Parameters No setting

Routing Parameters No setting

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet/CC IE/MELSECNET

7/8/2026

[Ethernet/CC IE/MELSECNET]

	Module 1	Module 2	Module 3	Module 4
Network Type	Ethernet	None	None	None
Start I/O No.	0070	-	-	-
Network No.	1	-	-	-
Total Stations	-	-	-	-
Group No.	1	-	-	-
Station No.	2	-	-	-
Mode	Online	-	-	-
	Operation Setting Exist	-	-	-
	Initial Setting None	-	-	-
	Open Setting Exist	-	-	-
	Router Relay Parameter Exist	-	-	-
	Station No.<->IP Information None	-	-	-
	FTP Parameters None	-	-	-
	E-mail Setting None	-	-	-
	Interrupt Settings None	-	-	-
	-	-	-	-

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet/CC IE/MELSECNET

7/8/2026

[Ethernet/CC IE/MELSECNET]

	Module 5	Module 6	Module 7	Module 8
Network Type	None	None	None	None
Start I/O No.	-	-	-	-
Network No.	-	-	-	-
Total Stations	-	-	-	-
Group No.	-	-	-	-
Station No.	-	-	-	-
Mode	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet/CC IE/MELSECNET

7/8/2026

[Ethernet/CC IE/MELSECNET]

	Module 9	Module10	Module11	Module12
Network Type	None	None	None	None
Start I/O No.	-	-	-	-
Network No.	-	-	-	-
Total Stations	-	-	-	-
Group No.	-	-	-	-
Station No.	-	-	-	-
Mode	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet/CC IE/MELSECNET

7/8/2026

[Ethernet/CC IE/MELSECNET]

	Module13	Module14	Module15	Module16
Network Type	None	None	None	None
Start I/O No.	-	-	-	-
Network No.	-	-	-	-
Total Stations	-	-	-	-
Group No.	-	-	-	-
Station No.	-	-	-	-
Mode	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-
	-	-	-	-

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet Operation Setting

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[Communication Data Code]
ASCII Code

[Initial Timing]
Always wait for OPEN (Communication possible at STOP tim

[IP Address]
192.168.26.141 (C0.A8.1A.8D)

[Online Change]
Allowed

[Send Frame Setting]
Ethernet(V2.0)

[TCP Existence Confirmation Setting]
Use the KeepAlive

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet Initial Setting

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[Timer Setting]

	Setting Value	Default Value	In Unit
TCP ULP Timer		60	X 500ms
TCP Zero Window Timer		20	X 500ms
TCP Resend Timer		20	X 500ms
TCP End Timer		40	X 500ms
IP Assembly Timer		10	X 500ms
Response Monitoring Timer		60	X 500ms
Dest. Confirmation Start Interval		1200	X 500ms
Dest. Confirmation Interval		20	X 500ms
Dest. Confirmation Resend		3	Times

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet Initial Setting

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[DNS Setting]

IP Address of DNS Server1 - (-)

IP Address of DNS Server2 - (-)

IP Address of DNS Server3 - (-)

IP Address of DNS Server4 - (-)

Network Parameter
Data Name : Ethernet/CC IE/MELSENET
Ethernet Open Setting

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[Open Setting]

	Protocol	Open System	Fixed Buffer	Fixed Buffer Communication Procedure	Pairing Open	Existence Confirmation	Host Station Port No.	Destination IP Address	Destination Port No.
1	TCP	Unpassive	Receive	Procedure Exist	Disable	No Confirm	3003 (0BBB)		
2	TCP	Unpassive	Send	Procedure Exist	Disable	No Confirm	3003 (0BBB)		
3	TCP	Unpassive	Receive	Procedure Exist	Disable	No Confirm	3004 (0BBC)		
4	TCP	Unpassive	Send	Procedure Exist	Disable	No Confirm	3004 (0BBC)		
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									

Network Parameter

Data Name : Ethernet/CC IE/MELSECNET

Ethernet Router Relay Parameter

Ethernet Board No. 1

Start I/O No. 0070

[Router Relay Parameter]

Router Relay Function Not Used

Subnet Mask Pattern 255.255.255.0 (FF.FF.FF.00)

Default Router IP Address 192.168.26.1 (C0.A8.1A.01)

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet Router Relay Parameter

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[Router Information]

No.	Sub-net Address	Router IP Address
1	- (-)	- (-)
2	- (-)	- (-)
3	- (-)	- (-)
4	- (-)	- (-)
5	- (-)	- (-)
6	- (-)	- (-)
7	- (-)	- (-)
8	- (-)	- (-)

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Ethernet FTP Parameters

7/8/2026

Ethernet Board No. 1
Start I/O No. 0070

[FTP Parameters]

FTP	Not Used	
Login Name	QJ71E71	
Password	Setting	
Command Input Monitoring Timer	1800	X 500ms
PLC Monitoring Timer	10	X 500ms

Network Parameter
Data Name : Ethernet/CC IE/MELSECNET
Acknowledge XY Assignment

7/8/2026

[Acknowledge XY Assignment]

XY No.	Type		Slot	Module Type	Points	Model Name	Duplication
	Network	I/O Assignment					
0000		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0010		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0020		I/O Assignment	1(0- 1)	Input	32 Points		
0030		I/O Assignment	1(0- 1)	Input	32 Points		
0040		I/O Assignment	2(0- 2)	Output	32 Points		
0050		I/O Assignment	2(0- 2)	Output	32 Points		
0060		I/O Assignment	3(0- 3)	Input	16 Points	QX40	
0070		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	
0080		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	

Network Parameter
Data Name : CC-Link
CC-Link Setting

7/8/2026

[CC-Link Setting]

Number of Modules Boards

Network Parameter
Data Name : CC-Link
CC-Link Setting

7/8/2026

[CC-Link Setting]

	1	2	3	4
Start I/O No.	-	-	-	-
Type	-	-	-	-
Master Station Data Link Type	-	-	-	-
Mode	-	-	-	-
Total Module Connected	-	-	-	-
Remote input(RX)	-	-	-	-
Remote output(RY)	-	-	-	-
Remote register(RW _r)	-	-	-	-
Remote register(RW _w)	-	-	-	-
Ver.2 Remote input(RX)	-	-	-	-
Ver.2 Remote output(RY)	-	-	-	-
Ver.2 Remote register(RW _r)	-	-	-	-
Ver.2 Remote register(RW _w)	-	-	-	-
Special relay(SB)	-	-	-	-
Special register(SW)	-	-	-	-
Retry Count	-	-	-	-
Automatic Reconnection Station Count	-	-	-	-
Standby Master Station No.	-	-	-	-
PLC Down Select	-	-	-	-
Scan Mode Setting	-	-	-	-
Delay Time Setting	-	-	-	-
Remote Device Station Initial Setting	-	-	-	-
Interrupt Settings	-	-	-	-

Network Parameter
Data Name : CC-Link
Acknowledge XY Assignment

7/8/2026

[Acknowledge XY Assignment]

XY No.	Type		Slot	Module Type	Points	Model Name	Duplication
	Network	I/O Assignment					
0000		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0010		I/O Assignment	0(0- 0)	Intelligent	32 Points	QD77MS4	
0020		I/O Assignment	1(0- 1)	Input	32 Points		
0030		I/O Assignment	1(0- 1)	Input	32 Points		
0040		I/O Assignment	2(0- 2)	Output	32 Points		
0050		I/O Assignment	2(0- 2)	Output	32 Points		
0060		I/O Assignment	3(0- 3)	Input	16 Points	QX40	
0070		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	
0080		I/O Assignment	4(0- 4)	Intelligent	32 Points	QJ71E71-100	