

WTP OPERATOR CHECKLIST

WTP OPERATOR CHECKLIST

Operator Reference Resource

Purpose

This resource is useful enough to help asset owners identify issues, keep useful records, and decide when to escalate – it is not a repair guide, design guide, or compliance certificate.

Daily and weekly walk-through checklist for remote and regional water treatment plants.

Important Scope Note

This guide is general information only. It is not a plant operations manual, commissioning procedure, process tuning guide, or substitute for site-specific operator training.

Use it to identify abnormal conditions, keep useful records, and know when to escalate. Do not use it to change process settings, alter control logic, bypass alarms, or troubleshoot beyond the site procedure.

What This Guide Helps You Do

- Complete a practical plant walk-through.
- Record abnormal conditions clearly.
- Identify when a fault needs support.
- Keep enough information for a useful follow-up review.

What This Guide Does Not Cover

- Process optimisation.
- Chemical dose adjustment.
- SCADA programming.
- Alarm setpoint changes.
- Wet commissioning.
- Validation testing.
- Detailed fault diagnosis.

Daily Walk-Through Checklist

Area	Operator Check	Status	Notes
Raw water	Source water available; no obvious abnormal colour, odour or debris issue.	Normal / Watch / Escalate	
Chemical storage	Chemical levels visible and suitable for normal operation period.	Normal / Watch / Escalate	
Dosing equipment	Pumps running as expected; no obvious leaks, blocked lines or abnormal noise.	Normal / Watch / Escalate	
Filtration	Filters operating in expected sequence; no abnormal pressure or flow behaviour.	Normal / Watch / Escalate	
Disinfection	UV, chlorine or nominated disinfection system operating; no critical alarm present.	Normal / Watch / Escalate	
Analyser rack	Readings visible and updating; no obvious sample flow issue.	Normal / Watch / Escalate	
SCADA / telemetry	Screens live; communications available; alarms reviewed.	Normal / Watch / Escalate	

WTP OPERATOR CHECKLIST

Area	Operator Check	Status	Notes
Plant area	Access clear; leaks, spills and trip hazards checked.	Normal / Watch / Escalate	
Logbook	Abnormal events and actions recorded.	Complete / Incomplete	

Weekly Checks

Area	Weekly Check	Notes
Logbook	Review repeated alarms, trends or recurring observations.	
Housekeeping	Check dosing area, sampling points, drains and accessways.	
Visible pipework	Look for leaks, vibration, loose supports or corrosion.	
Spares	Confirm agreed spares and consumables are present and stored correctly.	
Safety items	Check signage, eyewash, spill kit and access condition where applicable.	
Remote support	Confirm telemetry and alarm notifications are working as intended.	

Stop And Call Points

Escalate if:

- A critical alarm persists.
- Disinfection is unavailable or unreliable.
- Dosing equipment fails or appears to be dosing incorrectly.
- Water quality readings are abnormal and cannot be explained.
- Communications or telemetry are unavailable for an extended period.
- The plant cannot hold stable operation.
- The site reading does not match the SCADA indication.

Logbook Prompts

Useful entries answer:

- What changed?
- When did it start?
- Which alarm or reading was affected?
- What action was taken under the site procedure?
- Who was notified?
- What needs follow-up?

Operator Boundaries

Do not:

- Adjust process settings without approved site procedure.
- Override or silence repeated alarms without escalation.
- Treat recurring faults as normal.
- Run failing equipment without notifying the responsible person.
- Use this checklist as a commissioning or troubleshooting procedure.

WTP OPERATOR CHECKLIST

Next Step

If the plant is showing repeated alarms, unstable trends, logbook gaps or remote support issues, the next step is a plant review — not extended workaround operation.

PC Water Solution supports remote and regional WTPs across Australia and the Pacific with condition reviews, operator support, commissioning, and practical handover documentation that operators can actually use.

Arrange a WTP plant review — call 1300 029 804, email info@pcwater.com.au, or visit pcwater.com.au.