

Inspection workflow

- 1) Client submits application form to the customer liaison
- 2) SCSO or lead artisan assigns the inspection to an artisan
- 3) Artisan fills in EI17 (inspection report)
- 4) If it passes EI6 is completed inspection clearance certificate
✓ should be set electronically to the client
- 5) If it fails EI1 inspection of installation with list of defects requiring attention ~~a~~ should be set electronically to the client
- 6) For reinspection client submits EI1 and receipt to the customer liaison and the process restarts

ମ

The electrical installation comprising

on the property * owned/occupied by _____

[illegible]

INSTALLATION INSPECTOR

Date _____



Zimbabwe Electricity Supply Authority

E1

TO: Distribution:

Service No.....

1. CONSUMER OR OWNER
2. CONTRACTOR
3. DISTRICT MANAGER
4. OFFICIAL I/C OF DEPOT (OR INSTALLATION
INSPECTOR IF INSPECTION BY DEPOT OFFICIAL)
5. TO BE RETAINED IN BOOK

INSPECTION OF INSTALLATION

Sir,

You are hereby notified that the electrical installation on STAND/PLOT/.....

SUB. DIV. No FARM/MINE.....

..... DISTRICT/TOWNSHIP

has been inspected and that certain defects, a list of which is given below, require your attention.

This installation will be reinspected on receipt of a Notification of Completion of Wiring Form E.38 and the reinspection

fee of \$ due in terms of the Authority General Conditions of Supply Schedule of prescribed Fees.

DATE:..... SIGNED

REF:..... DESIGNATION:.....

LIST OF DEFECTS REQUIRING ATTENTION

N.B. After connection to the Mains the tests and inspections made by the Authority in no way relieve the Consumer of any responsibility in regards its subsequent maintenance of his electrical installation.

INSPECTION REPORT

REASON FOR INSPECTION: New Installation/Routine/Change of Tenancy.

1. Name of Consumer.....
Property Supplied.....
2. Property Owner's Name.....
Address.....
3. Contractor.....
Address.....
4. Size of Mains..... Size of Mains conduit.....
5. Consumer's main switch (a) Type..... (b) Capacity..... (c) Setting.....
6. Are neutrals fused?..... Neutral block fitted.....
7. Has a Consumer's earth electrode been installed, YES/NO. Type.....
8. Are all switches, starters, motors, conduits, cable sheaths, etc. bonded and earthed?.....
9. Insulation Resistance Tests. Between..... To earth.....
10. Earth continuity resistance.....ohms.
11. Polarity of switches/plugs. (If any are incorrect, state which).....
12. Are all earthing pins of socket outlets earthed?.....
13. Type of socket outlets.....
14. Type of wiring.....
15. Are circuit conductors of correct size?.....
16. Condition of wiring (cleats, insulation, ceiling-tubes etc).....
17. Flexible cord in prohibited positions. State where.....
18. Is bathroom switch accessible from bath? YES/NO. Are any unearthed, metal-clad switches installed earth situations?
If so state where.....
19. Are conduits (a) Bushed?..... (b) Bonded to earth?.....
(c) Of correct size?..... (d) Adequately supported?.....
(e) Of suitable type?.....
20. Maximum number of (a) Lighting points per circuit.....
(b) Plug points per circuit.....
21. Total number of lighting points.....
22. Total number of plug points.....
23. Details of Appliances and Wattages.....
24. Number and size of motors, and plant driven.....
25. Are overhead lines satisfactory as regards
(a) Height?..... (b) Conductor size?.....
(c) Support?..... (c) General?.....
26. Are overhead earthwires fitted to lines?.....
27. Are overhead lines suitably protected?.....
28. Are all outbuildings protected by main switches?.....
29. Are motor installations suitably protected?.....
30. Commission's switch details:.....
31. Supply left connected / disconnected.....
32. Has Contractor been notified of defects?.....
33. Any other features of the installation requiring attention.....

Date..... Signature