



CHECKLIST FOR ELECTRICAL SITES

This checklist is based on the Electricity (Supply) regulations, 1961 and shall be read in conjunction with the following Acts and Regulations and amendments thereof; Electricity Act (chap 13:19) of 2002, Energy Regulation Act (chap 13:23) of 2011, Electricity (Licensing) Regulations 103 of 2008, the Zimbabwe Grid Code, the Zimbabwe Distribution Code.

NAME OF RESPONSIBLE OFFICIAL			
SITE			
LOCATION			
Inspected by:		Signature:	Date:
A	Electricity (Supply) regulations		
	General	reference	Status
1	Availability of regulations	Sect 19	
2	Protection of telegraphs	Sect 15	
3	Access to licensees works (eg fences and durawalls)	Sect 16	
4	Danger Warning signs	Sect 28(2)	
5	Guidance & instructions	Sect 17	
B	Substations		
5	Rating of equipment (transformers)	Sect 20	Rating of load
6	Protection from HV conductors (clearance)	Sect 20(3)	
7	Protective barrier (live parts)	Sect 20(3)	
8	Earthing of metal works & equipment	Sect 29	
9	Metallic protection of HV cables	Sect 36	
10	Records of periodic testing and inspections	Sect 45	
11	Unauthorized climbing	Sect 47	
C	Licence conditions & Grid code requirements on Power Quality		
12	Frequency levels	5.2.6- sect 3.3.1	
13	Harmonics	5.2.7- sect 3.3.2	
14	Voltage variations	5.2.8- sect 3.3.3	
15	Unbalanced voltages	5.2.9- sect 3.3.4	
16	Flicker severity	5.2.10- sect 3.3.5	
17	Power Factor	5.2.12 – > 0.9	
18	Switching logs	5.2.17	
19	Safety documents	5.2.17	
D	Other		
20	Fire extinguishers		
21	Substation weeds & stones		
22	Labelling of circuits		

COMMENTS

I acknowledge the contents of the document as having been served upon me by the above named official:

Name of responsible official:

Signature:

Date:

Designation: