

## INSPECTION REPORT

Service No. ....

REASON FOR INSPECTION: New Installation/Routine/Change of Tenancy.

1. Name of Customer .....  
Property Supplied .....
2. Property Owner's Name .....  
Address .....
3. Contractor .....  
Address .....
4. Size of Mains ..... Size of Mains conduit .....
5. Customer's main switch (a) Type ..... (b) Capacity ..... (c) Setting .....
6. Are neutrals fused? ..... Neutral block fitted .....
7. Has a Consumer's earth electrode been installed, YES/NO. Type .....
8. Are all switches, starters, motors, conduits, cable sheaths, etc. bonded and earthed? .....
9. Insulation Resistance Tests. Between ..... To earth .....
10. Earth continuity resistance ..... ohms.
11. Polarity of switches/plugs. (If any are incorrect, state which) .....
12. Are all earthing pins of socket outlets earthed? .....
13. Type of socket outlets .....
14. Types of wiring .....
15. Are circuit conductors of correct size? .....
16. Condition of wiring (cleats, insulation, ceiling-tubes etc) .....
17. Flexible cord in prohibited positions. State where.....
18. Is bathroom switch accessible from bath? YES/NO. Are any unearthed, metal - clad switches installed in earth situations  
If so state where .....
19. Are conduits (a) Bushed? ..... (b) Bonded to earth ?.....  
(c) Of correct size ? ..... (d) Adequately supported.....  
(e) Of suitable type ? .....
20. Maximum number of (a) Lighting points per circuit.....  
(b) Plug points per circuit .....
21. Total number of lighting points .....
22. Total number of plug points .....
23. Details of Appliances and Wattages .....
24. Number and size of motors, and plant driven .....
25. Are overhead lines satisfactory as regards .....  
(a) Height? ..... (b) Conductors size?.....  
(c) Support? ..... (d) General?.....
26. Are overhead earthwires fitted to lines?.....
27. Are overhead lines suitably protected?.....
28. Are all out buildings protected by main switches?.....
29. Are motor installations suitably protected?.....
30. Commission's switch details .....
31. Supply left connected / disconnected .....
32. Has Contractor been notified of defects? .....
33. Any other features of the installations requiring attention .....

Date .....

Signature .....

Designation .....

Printed@torquary 020-66744