

INSPECTION AND OVERHAUL OF CONSUMER'S SUBSTATIONS

Nº

0503

Name of Substation: Substation No.: Order No.:

Section: Hanging Irons / Platform

Basic start date and time:

Type of Const... Underline / Terminal

Basic finish date and time:

Mileage in km and Fleet No.

A. TRANSFORMERS:

Date:

As FoundAs Left

- | | <u>As Found</u> | <u>As Left</u> |
|---|-----------------|----------------|
| 1. Make : | | |
| 2. kVA : | | |
| 3. Voltage Ratio : | | |
| 4. Serial No.: | | |
| 5. ZETDC No.: | | |
| 6. Security of Mounting : | | |
| 7. Tank bonded to S/S Earth : | | |
| 8. L.T. Neutral bonded to S/S Earth : | | |
| 9. Condition of Bushings : | | |
| 10. Condition of Paintwork : | | |
| 11. Arcing Horn Settings : | | |
| 12. Type of Breather (Sil. Gel. And / or | | |
| 13. Condition of Breather (Sil. Gel. And / or | | |
| Oil must be changed) : | | |
| 14. Oil Leaks (where?) : | | |
| 15. MEGGER (HT - E : | | |
| (LT - E : | | |
| (HT - LT : | | |
| (HT - LT/E : | | |
| (Oil Temperature : | | |
| 16. Oil Test Results (12f G/G etc) : | | |
| 17. Tap Range + % Tap Position : | | |

B. A.C.B. or O.C.B. :

- | | |
|---|--|
| 1. Make : | |
| 2. Type (A.C.B. or O.C.B.) : | |
| 3. Voltage Rating : | |
| 4. Current Rating : | |
| 5. ZETDC Number : | |
| 6. Trip Setting : | |
| 7. Condition of Oil : | |
| 8. Condition of contacts : | |
| 9. Dash Pots clean and properly filled : | |
| 10. All nuts and connection right : | |
| 11. Consumer A.C.B. / O.C.B. Trip Setting : | |
| (this must be lower than ZETDC ACB / OCB) | |

C. METERING TEST DATE _____ CONSTANT RX : _____

1. Make :
2. Amps :
3. Volts :
4. Maker's Type (s) :
5. Maker's Serial No (s) :
6. E.S.C. No (s) :
7. V.A.D. Transformer E.S.C. No.:
8. C.T. Ratio :
9. Meter Protection or type :
10. Meter cases earthed :
11. Condition of Potential fuses :
12. Potential Phase Rotation :
13. All connections tight ? :
14. All metering equipment fully sealed :
15. Meter Reading Card (s) available :
16. Voltage :

D. METER / SWITCH GEAR HOUSING

1. Type (Cubicle or House) :
2. Housing Weatherproof ? :
3. Weatherproof door fitted :
4. Condition of Paintwork :
5. Water outlet in conduit :
6. Door fitted with bar and two padlocks ? :
7. E.S.C. padlock lubricated ? :

E. 'D' FUSES

1. Rating and type (see E.1. 2/1)
2. Gauze washers fitted :
3. Holders drop freely :
4. Holders make good contact ? :
5. Contacts dressing and treated with anti-scuffing paste ? :

F. H.T. LIGHTING ARRESTERS

1. Make and type :
2. Voltage Rating :
3. Connected on loadside of 'D' fuses ? :
4. Arrester rails connected direct to transformer Tank before going to S/S Earth ? :

No 0497

G. L.T. LIGHTING ARRESTERS

1. Make :
2. Voltage Rating :
3. kVAR Rating :
4. Capacitor satisfactory as per
Section 5 of E.I. 32/2 :

H. SUBSTATION GENERAL

1. Total Earth Resistance :
2. Number of Earth electrodes :
3. Structures, crossarms, overhead earthwire
all bonded to S/S Earth ? :
4. L.T. Cable sheath or conduit bonded
to S/S Earth ? :
5. Conditions of L.T. Mains :
6. Conditions of poles :
7. Condition of Paintwork :
8. Site clear of undergrowth :
9. Site accessible for vehicle :
10. Type and length of L.T. Mains :

I. SAFETY PRECAUTIONS

1. Danger Notice (s) fitted ? :
2. Anti-climb device (s) fitted ? :

J. CONSUMER'S INSTALLATION

General Condition :

REMARKS :

Date :

(Signed) :