

Document No:	Title :Plant Maintenance	Number of Pages :
Document Type: Procedure	Revision: 0	Effective Date :

1. PURPOSE

For all plant and equipment maintenance

2. SCOPE

This procedure applies to all maintainable plant and equipment in ZETDC Eastern Region.

3. RESPONSIBILITIES

- 3.1 The Operations and Maintenance Engineer is responsible for ensuring that this procedure is implemented, maintained and regularly reviewed in line with the changes in operations, technology, legislation, standards, circumstances and policies

4. DEFINITIONS

- 4.1 **GM** – General Manager
- 4.2 **ME** – Maintenance Engineer
- 4.3 **Snr EM** – Senior Engineer Maintenance
- 4.4 **Form E16** – Overhaul Report
- 4.5 **Form E18** – Permit To Work
- 4.6 **Form E10** – Controller's Instruction Form
- 4.7 **Form E96A** – Sanction For Test
- 4.8 **Form E44** – Limitation Of Access
- 4.9 **NDM** – Network Development and Maintenance
- 4.10 **Form** – Pre-task Risk Assessment

5. ACTIVITY DESCRIPTION

1. The Snr Engineer Maintenance prepares the maintenance programme

Compiled by:	Designation:	Date:	Sign:
Checked by:	Designation:	Date:	Sign:
Approved by:	Designation:	Date:	Sign:
Motivation of revision: Launch of New Procedure			

Document No:	Title :Plant Maintenance	Number of Pages :
Document Type: Procedure	Revision: 0	Effective Date :

2. The Senior Engineer provides the Snr Foreman (Operations and Maintenance) with the maintenance programme
3. The Snr Foreman will check if it is a planned maintenance or a fault Maintenance
4. If it is a planned Maintenance, The Snr Foreperson (OPSMA) will tabulate the maintenance dates in order
5. The Snr foreperson (OPSMA) and the Technician will prepare all the required resources to use on the maintenance
6. The Snr Foreperson (OPSMA) will then liase with the Depot S/CSO/Controller for the proposed maintenance dates.
7. The Depot S/CSO/Controller will then communicate with the Marketing department on the issue of advertising to notify clients of the proposed date of shutdown.
8. The Markerting Officer will advertise in the Local Media (Newspapers, Radio and Television)
9. When **the** advert is done the S/CSO/Controller will inform the Snr Foreperson (OPSMA) of the agreed dates
10. The Snr Foreperson will then assign a Technician and also in SAP who will do the maintenance on the equipment
11. The S/CSO/Controller will then make the equipment to be worked on safe (switching) and release it for work by issue of a safety document
12. The **working team (in charge of work) will conduct a pre-task assessment before the work has started.**
13. The Technician and his team will work on the equipment.
14. Technician will carry out pre-commissioning tests.
15. Technician will clear all safety documents in force
16. Technician will inform the S/CSO/Controller who will cancel the safety document
17. Technician will inform Snr Foreperson (OPSMA) who will request for protection department to carry out tests
18. The S/CSO/Controller will issue safety test documents
19. Commissioning tests are carried out by protection
20. Safety Documents are cancelled by S/CSO/Controller after tests passing
21. Equipment is brought back into service by S/CSO/ Controller
22. The Snr Foreperson will then complete the job in SAP and attach all documents

6. RECORDS

The following records shall be generated from implementation of this procedure.

Name of record:	Custodian / location:	Retention period:	
Overhaul report	S/CSO / SNR Foreperson	5yrs	
Permit to Work	S/CSO	1 yr	
Sanction for Test	S/CSO	1 yr	
Compiled by:	Designation:	Date:	Sign:
Checked by:	Designation:	Date:	Sign:
Approved by:	Designation:	Date:	Sign:
Motivation of revision: Launch of New Procedure			

Document No:	Title :Plant Maintenance	Number of Pages :
Document Type: Procedure	Revision: 0	Effective Date :

Limitation of Access	S/CSO	1 yr
Wayleave Inspection Report	S/CSO	5 yrs
Substation Inspection Report	S/CSO	5 yrs
Pre-task Risk Assessment Form	S/CSO	1 yr

After the retention period of 5 years all the records shall be archived for a period of 30 years.

7. REFERENCES

- 7.1 Client Service Charter
- 7.2 Engineering Instructions
- 7.3 COSAD
- 7.4 Distribution Code
- 7.5 Electricity Act

Compiled by:	Designation:	Date:	Sign:
Checked by:	Designation:	Date:	Sign:
Approved by:	Designation:	Date:	Sign:
Motivation of revision: Launch of New Procedure			