

ZETDC EASTERN REGION		
REVISION: 1	DOCUMENT TYPE: PROCEDURE TITLE: EMERGENCY PREPAREDNESS AND RESPONSE	DOCUMENT NO: SHE 02
ISSUE DATE: 25/10/13 STATUS: CONTROLLED DOCUMENT	COMPILED BY: HEALTH & SAFETY OFFICER REVIEWED BY: CHIEF RISK OFFICER AUTHORISED BY: GENERAL MANAGER	SIGN: SIGN: SIGN:

1. PURPOSE

This procedure provides for the identification of, and response to accidents and emergency situations and for preventing and mitigating environmental impacts that may be associated with them.

2. SCOPE

This procedure covers emergency situations and accidents likely to occur in ZETDC Eastern Region and can have significant safety, health and environmental impacts.

3. RESPONSIBILITIES

3.1 The General Manager is responsible for ensuring implementation of this procedure

4. DEFINITIONS

- 4.1 GM – General Manager
- 4.2 EM- Engineering Manager
- 4.3 HRAM – Human Resource and Admin Manager
- 4.4 SCSO- Senior Client Services Officer
- 4.5 CRO – Chief Risk Officer
- 4.6 HSO – Health and Safety Officer
- 4.7 EMS -Environmental Management System.
- 4.8 OHS – Occupational Health and Safety
- 4.9 SAZS – Standards Association of Zimbabwe Standard.
- 4.10 ISO – International Organisation for Standardisation.

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

4.11 P - Procedure.

5. ACTIVITY DESCRIPTION

- 5.1 Identification of potential emergency situation and accidents shall be identified by a group of representatives from all departments.
- 5.2 The identification process shall consider normal and abnormal operations, identified environmental aspects and impacts and occupational hazards & risks.
- 5.3 Specific response plans for each identified emergency situation or accident shall be drafted.
- 5.4 Where practical emergency situations and accidents shall be tested and results of these tests shall be retained.
- 5.5 Frequency of emergency mocks shall be twice a year.
- 5.6 The fire and rescue team shall conduct a drill at least once a month.
- 5.7 Emergency equipment such as fire extinguishers, hose reels shall be serviced at least once every year.
- 5.8 Emergency preparedness and response procedures shall be reviewed after the occurrence of an accident or emergency situation.
- 5.9 The Group Stakeholder Relation Manager shall do any external communication to the press regarding an emergency situation or accident.
- 5.10 Mitigatory action for the aftermath of emergencies shall be resolved through use of other procedures such as Waste Management Procedure

TEAM MEMBER	ROLE
1. General Manager	Chairman, coordinates activities in the Eastern Region
2. Engineering Manager	Alternative to Chairman Co-ordinates activities at the Regional Office
3. CRO	- Ensures security protection of company assets during and after an incident. - Liaises with law enforcement agents. - Directs and coaches Gate Security on communication during an emergency.

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

	- Controls all premise entry and exit points. - Investigates criminal activities under the guidance of the chairman. - Accident investigation
4. HSO	- Deals with crises concerning Health, Safety & Environmental issues - Coordination of first aid & fire fighting activities
5. Depot SCSO/ Network Manager	- Deals with infrastructure and engineering issues - Shut down of equipment & machinery - Isolation of electricity & hazardous material supplies

6. RECORDS

The following records shall be generated from implementation of this procedure.

Name of record:	Custodian / location:	Retention period:
Emergency mock drill report	HSO/ Depot Foreperson	3 years
Emergency drill plan	HSO/ Depot Foreperson	3 years

7. REFERENCES

7.1 SAZS ISO 14001:2004 Clause 4.3.2.

ZETDC EASTERN REGION		
REVISION: 1	DOCUMENT TYPE: PROCEDURE	DOCUMENT NO: SHE 02
	TITLE: EMERGENCY PREPAREDNESS AND RESPONSE	
ISSUE DATE: 25/10/13	COMPILED BY: HEALTH & SAFETY OFFICER	SIGN:
STATUS: CONTROLLED DOCUMENT	REVIEWED BY: CHIEF RISK OFFICER	SIGN:
	AUTHORISED BY: GENERAL MANAGER	SIGN:

**APPENDIX 1: LIST OF POTENTIAL SAFETY HEALTH & ENVIRONMENTAL
EMERGENCY SITUATIONS AND ACCIDENTS**

Emergency situation	Potential source	Existing control measures
Fatality	Plant, Machinery	Health & safety management systems
Major injury	Plant & machinery	Health & safety management systems
Fire	Flammable & combustibles storage	Proper storage, Ignition controls
Bomb threat	Public & employees	Good public relations
Civil unrest and riots	Public	Good public relations
Food poisoning	Canteen/ Kitchens	High hygiene standards & controls
Cholera	Contaminated food and water sources	High hygiene standards & controls
Substation emergency	Electrical/ veld fires	Fire extinguishers & fire guards
Robbery/ burglary / armed and hostile intruder	Public	Nil
Floods	Rain water	Nil

APPENDIX 2 – EMERGENCY PREPAREDNESS & RESPONSE PLAN – FATALITY

PREPAREDNESS PLAN

1. Occupational Health and Safety awareness across the Region.
2. Posting of safety signs

RESPONSE PLAN

1. When a fatality happens the person who witnesses the fatality first should immediately notify the responsible person (Security, Supervisor, SCSO, or Manager).
2. The responsible person should immediately notify the GM, Network Manager, HSO, CRO and Head of Department.
3. The site where the accident has occurred should be barricaded and no person shall disturb the site at which the accident occurred before arrival of the factories inspector

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

or police or his consent unless disturbance is done to prevent further accidents or to remove dead bodies.

4. The GM or his appointee shall immediately communicate about the fatality to the police and/ factories inspector.
5. The Depot Foreperson/ Garage Foreperson/ HSO shall record the accident details in the accident register
6. The Group Stakeholder Relation shall be responsible for all external communication about the fatality if there is need to do so.
7. The HRA Manager shall be responsible for communicating the death to the next of keen.
8. The Maintenance Engineer shall lead the accident investigation and a report of this investigation issued out.
9. SCSO shall declare that the emergency is over and order employees to return to their respective workstations in consultation with responsible Authority.
10. Action plans to close the identified gaps shall be implemented and tracked to completion.

APPENDIX 3 - EMERGENCY RESPONSE PLAN – MAJOR ACCIDENT

PREPAREDNESS PLAN

1. Occupational Health and Safety awareness across the Region.
2. Posting of safety signs

RESPONSE PLAN

1. If a major accident occurs within the premise the person who notices the accident first, Supervisor, Foreman, Manager or responsible person in the department where the accident occurred shall immediately notify the First Aider and the person will be given the necessary assistance until an ambulance arrives.
2. If there is no trained first aider the patient should be kept safe until the ambulance arrives.
3. The responsible Supervisor, Foreman, Manager or Security Officer shall call EMRAS to come and pick up the patient and send him/her to hospital.
4. The Departmental Manager, Depot Foreperson, CRO, Network Manager and HSO should immediately be notified about the accident.

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

5. Where the injured is admitted in hospital the departmental Manager shall ensure that the next of kin is informed about the casualty's whereabouts.
6. The HSO, Depot or Garage Foreperson shall record the accident details in the accident register and report the accident to the Factories inspectorate.
7. The responsible Head of Department shall lead the accident investigation and a report of this investigation issued out.
8. The Group Stakeholder Relation shall do communication to the media concerning the accident if they need to know

APPENDIX 4 - EMERGENCY PREPAREDNESS & RESPONSE PLAN – FIRE

PREPAREDNESS STRATEGY

1. There shall be a trained team of fire fighters and first aiders across the Region.
2. Fire risk surveys shall be done every six months
3. The emergency team, fire fighters and first aiders shall carryout drills every month.
4. The fire fighting equipment shall be serviced at least once every year.
5. During servicing of fire fighting equipment, employees shall be trained on the use of fire fighting equipment.
6. Fire fighting equipment inspections shall be done every two months to check on adequacy.
7. Reverse parking shall be enforced in the premise for all vehicles that have parking lots in the premise.

RESPONSE

1. Any person who discovers a fire should immediately call security, the switchboard number, or raise an alarm.
2. Ensure that all sources of energy are shut off.
3. If trained try to extinguish the fire with available fire fighting equipment if it is safe to do so.
4. Security or switchboard should immediately notify the Fire brigade giving the exact details of the location of the fire and entrance to be used.
5. All the people should immediately evacuate the building to their Assembly points or to any other area if there is risk at the assembly point.
6. Security should also call in the ambulance if there are any injuries.

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

7. The GM, responsible Head of department, CRO, Forepersons and HSO should be notified.
8. Security should ensure that all entrances are clear and open to allow emergency rescue services access to the premise.
9. Security should restrict access into the premise during the emergency.
10. When the Fire Brigade arrives there should be Fire Marshall or person at the gate to direct them to the exact location of the incident.
11. On arrival fire brigade takes over command.
12. The Chief Fire Officer or the leader of the Fire Brigade will declare safe when the emergency is fully contained.

APPENDIX 5 - EMERGENCY PREPAREDNESS & RESPONSE PLAN –BOMB

THREAT

PREPAREDNESS PLAN

1. Awareness on what to do in an event of a bomb threat to be done
2. External directory includes the Army's bomb Unit

RESPONSE PLAN

1. Any person who receives a bomb threat message should if possible direct the call to CRO using another line.
2. Listen attentively to the threat and calmly request for details (location, identity etc) and reasons and try to keep the caller on the line whilst trying to let a Manager, switchboard, Loss Control Personnel aware.
3. The security or switchboard should immediately call the GM and police or Zimbabwe National Army.
4. Standby for instructions and be ready to evacuate.
5. GM, Network Manager, Depot Foreperson, CRO and all Supervisors should be notified.

APPENDIX 6 – EMERGENCY PREPAREDNESS & RESPONSE PLAN - FOOD

POISONING

PREPAREDNESS PLAN

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

1. Ambulance services available when cases need outside management

RESPONSE PLAN

1. Any employee suffering from food poisoning should be send to hospital.
2. The First aider or supervisor should immediately notify the HSO and HRO of any food poisoning outbreak (more than 10 people affected at the same time) and investigations should immediately start.
3. Samples of the food consumed should be collected and sent to the laboratory for analysis.
4. Further serving of the food that caused food poisoning should be stopped.
5. All the other HODs/ Forepersons should be notified of the incident.

Appendix 7-Cholera Outbreak

Preparedness Plan

1. Cholera awareness across the Region
2. Posting of Cholera Alert Signs
3. Preparation of Bottled Salt & Sugar Solution(SSS)

Response Plan

1. Employees with any form of diarrhoea to report to Supervisor/ First aider
2. Aqua tablets to be purchased for use by all employees
3. Purchase of Hand sanitizer for use by food handlers
4. Canteen/ kitchen employees to undergo routine stool test on a weekly basis
5. Ensure adequate stockholding of toiletries in the wash rooms at all times (toilet paper, washing soap, paper towelling). Absolutely no use of towels.
6. Employees to alert management of any inadequacies.

APPENDIX 8 - EMERGENCY PREPAREDNESS & RESPONSE PLAN –CIVIL

UNREST AND RIOTS

PREPAREDNESS PLAN

1. Nil

RESPONSE PLAN

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

1. In the event of civil unrest and riots all employees within premises should remain inside.
2. Company assets should be safeguarded through lock out and tagging and shutdowns.
3. Entrance into the premises should be restricted and avoid interaction with people outside the premises.
4. The GM, CRO and Police should be notified.

APPENDIX 9 - ELECTRICAL SUBSTATION EMERGENCY PREPAREDNESS PLAN

1. Fire extinguishers

RESPONSE PLAN

1. Any emergency situations at Electrical Substations are immediately reported to the Network Manager or any other person charged with engineering responsibilities and the area immediately cordoned off and isolated.
2. In emergencies where specialist services are required, the supervisor on site or any responsible person contacts the relevant authorities for assistance. The emergency contact numbers are found on the Directory of the Emergency Response Team and Key Contacts which are readily found on notice boards and offices.
3. Only competent and authorised personnel are allowed to access and rectify the emergency.
4. Only dry powder and carbon dioxide fire extinguishers must be used to extinguish any fires that occur at substations.

APPENDIX 10 - ROBBERY /BURGLARY (ARMED AND HOSTILE INTRUDER)

PREPAREDNESS PLAN

1. Security guards
2. Access control

RESPONSE PLAN

1. Stay calm and think -Your safety comes first
2. Follow orders
3. Bring people away from dangerous area

TITLE: EMERGENCY PREPAREDNESS AND RESPONSE		DOCUMENT NO: OHS 02
ISSUE DATE: 25/10/13	REVISION: 0	
STATUS: CONTROLLED COPY		

4. First person to call security immediately the situation is under control

Observe carefully:

1. Physical characteristics
2. Stolen things or materials
3. Direction of escape
4. Transportation used
5. Do not touch or move anything
6. Order any witness to stay.

APPENDIX 11- FLOODS

PREPAREDNESS PLAN

There are several types of floods possible in Zimbabwe and these include river flooding, flash floods and dam failure. All floods tend to be a predictable risk to life and property. First defence is to minimize human activity in areas and in times of potential flooding

RESPONSE PLAN

1. Stay away from flood waters
2. Call in the Emergency Response Team.
3. Move to high ground and call for help.
4. If trapped climb to the top of buildings or trees.
5. Stay away from drowned or damaged electrical power lines
6. Do not cross a flooded river whether on foot or by vehicle.

EMERGENCY RESPONSE TEAM

1. Proceed to the scene of the flood and assess the situation.
2. Take all necessary precautions to prevent electrocution, falls from heights or crushing by falling trees or moving logs and boulders.
3. Evacuate all people to safe areas and rescue those trapped where possible.
4. Contact Civil Protection.
5. Team leader to give feedback to the Emergency Preparedness and Response Committee dealing with the emergency.