

MONTHLY BATTERY AND CHARGER MAINTANANCE SCHEDULE

FOR 50V NICKEL CADMIUM (NYCAD OR NIFE)

DATE :

SUBSTATION:

1.Record Charger Float Voltage

If float voltage is not 56 volts readjust float
Potentiometer.

2.Record charger current

SWITCH OFF CHARGER

3.Record battery voltage

(Voltage should not drop below 48v)

4. Record minimum cell voltage

Voltage should not be below 1.2 v

5. Apply load test (if provided)

Record volts with charger still off after 1 minute

6.Top up cells with distilled water to maximum level.

Thoroughly mix electrolyte using hydrometer.

7. Clean terminals and cell cases.

8. Check terminal connections.

SWITCH ON CHARGER

9.Ensure float voltage remains constant at 56 volts after 15 minutes.

SIGNATURE: