

ELECTRICAL MAINTENANCE SECTION LINE INSPECTION REPORT

FORM E48

Page.....

Date

Depot

NOTE:

This Inspection is to be carried out from Ground Level

Diagrammatic Layout No.....Sheet No.....

1	Line and Voltage										
2	Section										
3	Structure Number										
4	Type of Construction										
5	Obstruction in Wayleave										
6	CONDITION OF POLES	STEEL	Requires Painting								
7			Corrosion Present								
8	WOOD	Termite Damage									
9		Dry Rot Damage									
10		Lightning Damage									
11		Badly Split									
12		Other Damage									
13	Crossarm Requires Attention										
14	INSULATORS	Flashover									
15		Broken									
16		Chipped									
17		Excessively Dirty									
18		Pin Bent									
19		Binder Loose or Broken									
20		Otherwise Faulty									
21	CONDUCTOR CONDITION	Ground Clearance Low									
22		Otherwise Faulty									
23	STAYS	Loose									
24		Corroded									
25		Insulator missing									
26		damaged etc, Otherwise Faulty									
27	EARTHING CONNECTIONS	Damaged Mechanically									
28		Corroded									
29		Stolen									
30		Not Protected									
31		Otherwise Faulty									
32	Cradle Requires Attention										
33	LINE INSULATORS	Switch No. Plate reqd									
34		Corrosion or Rust									
35		Insulators Damaged									
36		Contacts appear faulty									
37		Otherwise faulty									
38	Anti Climb Devices										
39	Other Equipment										

NOTES.:

Print Logistics 0773 790 836

Signed Designation.....