



Web site 網址 : <http://www.cedd.gov.hk>
 E-mail 電子郵件: mhtse@cedd.gov.hk
 Telephone 電話 : (852) 2762 5677
 Facsimile 傳真 : (852) 2714 0079
 Our reference 本署檔號: (0XY2H-01) In LW(CV/2011/01)/M25/110
 Your reference 米西檳號: (out)CRBC/CV201101/S210(4)/369

土木工程處
Civil Engineering Office

香港九龍公主道 101 號
土木工程拓展署大樓
Civil Engineering and
Development Building,
101 Princess Margaret Road,
Kowloon, Hong Kong

China Road and Bridge Corporation
Units 07-11, 23A/F., K. Wah Centre,
191 Java Road,
North Point, Hong Kong
(Attention: Mr. Ken KAU)

Dear Sirs,

Contract No. CV/2011/01
Site Formation and Infrastructural Works near Tsing Lun Road and Tsz Tin Road in Area 54, Tuen Mun

Material Submission -Tactile Tile, Draw Pit, Earth Pit, Kerb & Edging, Precast Concrete Unit for Valve Chamber and Gully Former

I refer to your letter of the above reference dated 9 November 2012 submitting further information for the above materials supplied by "Goodview Construction Materials Company Limited".

I have no further comments on your proposed draw pit, kerb & edging, precast concrete unit for valve chamber and gully former.

Regarding your proposed 300x300x60 (mm) precast concrete hazard warning slabs, please submit the test results for the bending strength of the paving slabs and compressive strength of concrete cubes at 28 days as per G.S. 11.68(1).

Besides, you are reminded to submit the manufacturer's certificate demonstrating compliance with GS Clause 16.21(1)(b) before each batch of precast concrete products are delivered to the Site.

Yours faithfully,

(TSE Man-hong)
Engineer's Representative
Land Works Division
Civil Engineering and Development Department