

Contractor's Material Related Submission

Hsin Chong Construction Co., Ltd.
RECEIVED
19 SEP 2013
BY: [Signature]

Restricted



Action: MSF - AIP (Re-submission Required)

Transmittal No: 908-ERFM-CM(SILC)-CS-000255

Project: South Island Line (East)

Contract: Wong Chuk Hang Depot Superstructure

Title: Goodview Brand - Precast Concrete Kerbs and Concrete Paving Block

From: LI Paul Kam Hung (李錦洪)(pp TSANG Henry Heung Keung (曾向強))

To: LUI Thomas C. W. (Hsin Chong Construction Co Ltd)

Date Sent: 18/09/13

Date Opened: 19/09/13

Due Date: 02/10/13

Cc: LI Paul Kam Hung (李錦洪); LI Chris Pul In (李佩妍); LEUNG Walter Sin Yu (梁晉儀); IU Alan Woon Lun (姚煥倫); CHOI SC Sheung Chin (蔡尚駿); TSANG Foster Chi Chung (Hsin Chong Construction)

Step No.: 2

Last Step: N

Turnaround Day:

Message: We have no objection in principle on the submission (Goodview Brand) subject to the following comments.
 1. The proposed Precast Road Kerb shall be in full compliance with GS 2006 cl. 11.51(1) & (2) and BS 7263.
 2. The test certificates including 28 days compressive strength shall be submitted at delivery on site.

Link From:

Link To:

Attachments

| Status | Title | Doc./Draw. No. | Parent Doc.No. | Doc. Date | Orig. Ref. No. |
|--------|-------|----------------|----------------|-----------|----------------|
|--------|-------|----------------|----------------|-----------|----------------|