

香港房屋委員會  
Hong Kong Housing Authority

Our Ref. : HD(MB)CE 3/388/109/11  
Your Ref. : HA20070055/HD/0139 dd 29Dec08  
Tel.: 2761 6991  
Fax.: 2761 7300

Date : 6 January 2009

Harvest Civil Engineering Co. Ltd.,  
Rm. 1005, 10/F Shing Chuen Ind. Bldg.,  
25-27 Shing Wan Road,  
Tai Wai, Shatin.

(Attn: Mr. Patrick M.Y. Chung – Site Agent)

Dear Sirs,

Contract No. 20070055  
Civil Engineering Improvement Works at Kai Yip Estate  
Material Submission – Paving Blocks

I refer to your letter ref. HA20070055/HD/0139 dated 29 December 2008 regarding the above-mentioned proposal.

I have no objection to your proposal of appointing "Goodview Construction Materials and Engineering Co., Ltd." as your supplier for paving blocks for this contract. Please note that your submitted paving block should be used in footways only but not in Emergency Vehicular Access (EVA) area.

Yours faithfully,



(Eva Y.W. MAK)  
Civil Engineer 6/M  
Contract Manager's Representative

c.c. PQS - Franklin and Andrews (Hong Kong) Ltd. (Attn : Mr. Y.W. Mak)  
Site - IOW/M, CSEG/74  
File via SCE/M





土木工程拓展署

Civil Engineering and  
Development Department

土木工程處

Civil Engineering Office

Web site 網址 : <http://www.cedd.gov.hk>  
 E-mail 電子郵件 : [bernardwoleung@cedd.gov.hk](mailto:bernardwoleung@cedd.gov.hk)  
 Telephone 電話 : (852) 2762 5325  
 Facsimile 傳真 : (852) 2714 0079  
 Our reference 本署檔號 : (18) in LW/(CV/2006/01)M25/110 pt. 5  
 Your reference 來函檔號 : CSHK/CAZ/MSF/0032/E

香港九龍公主道 101 號  
 土木工程拓展署大樓  
 Civil Engineering and  
 Development Building,  
 101 Princess Margaret Road,  
 Kowloon, Hong Kong

2 September 2008

By Fax

(Fax no.: 2865 5229)

China State Construction Engineering (Hong Kong) Ltd  
 29/F., China Overseas Building  
 139 Hennessy Road  
 Hong Kong  
 (Attn.: Mr. Ernest YEUNG)

Dear Sirs,

Contract No. CV/2006/01  
Ping Ha Road Improvement Works (Ha Tsuen Section)

Material Submission  
Concrete Paving Block (Goodview)

I refer to your submission referenced above dated 23 August 2008 providing supplementary information for the captioned.

I have no objection to your proposal of using concrete paving block manufactured by "Goodview Weiye Construction Materials Co. Ltd." and supplied by "Goodview Construction Materials & Engineering Co., Ltd." for the above Contract. Please strictly comply with the Contract requirements and the manufacturer's recommendations.

Yours faithfully,

(LEUNG Wah-on)

Engineer's Representative  
 Land Works Division

Civil Engineering and Development Department

c.c. Site Office  
 Site Agent (thro' SIOW)  
 File LW/(CV/2006/01)/M10

KFT/BL.MYL

13 Jun. 2008, 12:15

CSHK : Civil (27/F) W. CEDD

+ 852 27No. 1211 Y. 1/2



土木工程處

Civil Engineering Office

000417

Web site 網址 : <http://www.cedd.gov.hk>  
 E-mail 電子郵件 : [bernardwoleung@cedd.gov.hk](mailto:bernardwoleung@cedd.gov.hk)  
 Telephone 電話 : (852) 2762 5325  
 Facsimile 傳真 : (852) 2714 0079  
 Our reference 本署編號 : (23) in LW/(CV/2006/01)/M25/110 PC-3  
 Your reference 來函編號 : CSHK/CAZ/CSF/0032/B

香港九龍公主道 101 號  
 土木工程發展大樓  
 Civil Engineering and  
 Development Building,  
 101 Princess Margaret Road,  
 Kowloon, Hong Kong

11 June 2008

By Fax

(Fax no.: 2865 5229)

China State Construction Engineering (Hong Kong) Ltd  
 29/F., China Overseas Building  
 139 Hennessy Road  
 Hong Kong  
 (Attn.: Mr. Ernest Yeung)

Dear Sirs,

Contract No. CV/2006/01  
Ping Ha Road Improvement Works (Ha Tsuen Section)

Material Submission  
Concrete Paving Block and Precast Concrete Kerb

I refer to your submission referenced above dated 19 May 2008.

Concrete Paving Block

I have the following comments:

- i) Pursuant to GS Clause 11.68(1)(b), please submit a certificate from the manufacturer showing the particle size distribution of the aggregates; and
- ii) Referring to PS Clause 11.65A(3), please clarify with the manufacturer whether there is a shortage of supply of recycled aggregates so that we may consider their proposal for the use of virgin aggregates in lieu of recycled aggregates.

Precast Concrete Kerb

I have no objection to your proposal of using the precast concrete kerb (Type K1) manufactured by "Goodview Construction Materials & Eng. Co. Ltd" for the above Contract.

Yours faithfully

(LEUNG Wah-on)  
 Engineer's Representative  
 Land Works Division

Civil Engineering and Development Department

We bring the best engineering to life

興土木 利民生 齊拓展 創明天



MSF / re-submit

CHINA STATE CONSTRUCTION ENGINEERING (H.K.) LTD	
CV/2006/01	ACT (CPT) SIGN
RM	
AGENT	
EQUIPMENT	
ENG	
SURVEY	
POS	
1. SUPERVISOR	
SUPV. CHECK	
ENV	
QA	



Web site 網址 : <http://www.cedd.gov.hk>  
E-mail 電子郵件 : [raymondctkwok@cedd.gov.hk](mailto:raymondctkwok@cedd.gov.hk)  
Telephone 電話 : (852) 23051275  
Facsimile 傳真 : (852) 27074825  
Our reference 本署檔號 : GCST 4/20/9-13  
Your reference 來函檔號 :

香港九龍祥業街工務中央試驗所大樓  
工務試驗所

Public Works Laboratories,  
Public Works Central Laboratory Building,  
Cheung Yip Street,  
Kowloon, Hong Kong

13<sup>th</sup> December 2007

Goodview Construction Materials & Eng. Co., Ltd.,  
17/F Flat A Hing Lee Comm Bldg.  
12-14 Shanghai St.,  
Jordan, Kowloon  
(Attn: Mr. Danny Hui)

By fax : 2872 4779

Dear Mr. Hui,

**Laboratory Testing Service**

With reference to your letter dated 13 December 2007 requesting for our testing service, we are pleased to advise you the fee as follows :-

Testing of One set (5 Nos.) of clay pavers for the determination of unpolished skid resistance value to BS EN1344:2002 : HK\$1,189.00

Please note that the above-mentioned tests are not accredited by authorized bodies and therefore non-HOKLAS certificates will be issued after testing. If you would like our laboratory to carry out the tests, please indicate your acceptance to our fee and the conditions of service set out in the Public Works Laboratories Private Testing Services brochure as attached by signing and returning the duplicate copy of this letter within 14 days of the date of this letter. A Demand Note will be issued to you later. Please kindly settle the amount shown on the Demand Note within 14 days of the date of its issue and you will be informed for the delivery of sample for testing. The duration of testing will be about 2 weeks' time upon receipt of sample.

Yours faithfully,



( C.T. Kwok )

for Chief Geotechnical Engineer/S&T  
Geotechnical Engineering Office  
Civil Engineering & Development Department

I/We accept the above fee and conditions. Please carry out the testing. I want the test certificates/reports to be (collected by our staff/~~sent to us by post~~)\*.

Please stamp  
Company chop  
On the right .





Signature  
Name  
Position  
Name of Company  
Date

*Signature*  
: *Danny Hui*  
: *MANAGER*  
: *GOODNEW CONSTRUCTION*  
: *HAIPHONG, HANOI, VIETNAM*  
: *17/12/2007*

\* Please delete as inappropriate

To: MR. C.T. Kwok.

Fax: 27074825

<b>To:</b> Goldfield N&W Construction Company Limited  <b>Attn.:</b> Patrick Chow	<b>Contract No.</b> C5191 Yau Tong Playground Re-provision	 <b>地鐵公司</b> MTR Corporation																																																													
<b>ENGINEER'S DECISION SHEET TO CONTRACTOR'S SUBMISSION</b>																																																															
<b>Title of Submission</b> : External Clay Paving Tile																																																															
<b>Submission Number</b> : YTP/SPE+SAM/108																																																															
<b>RESPONSE</b> : AP Approved																																																															
<b>COMMENTS</b>  I have no adverse comment to your proposed Austral Bricks external clay paving tile, color code :Kirra and Miami (Paradise Series) as agreed in the LCSD's meeting held on 4 September 2007.																																																															
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">MTRC Distribution</th> </tr> <tr> <th>Route To</th> <th>Copy</th> <th>Org</th> <th>Comment</th> <th>Action</th> </tr> </thead> <tbody> <tr> <td><i>Blu</i></td> <td></td> <td><i>/</i></td> <td></td> <td></td> </tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> <tr><td> </td><td></td><td></td><td></td><td></td></tr> </tbody> </table>		MTRC Distribution					Route To	Copy	Org	Comment	Action	<i>Blu</i>		<i>/</i>																																																<b>From :</b> Engineer's Representative <b>Name :</b> Walter Lam  <b>Signature :</b>   <b>Date :</b> 20 September 2007	
MTRC Distribution																																																															
Route To	Copy	Org	Comment	Action																																																											
<i>Blu</i>		<i>/</i>																																																													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="5">           FILE No. C/PMOG/1KE/C5191/C3561/#786743         </td> </tr> </table>		FILE No. C/PMOG/1KE/C5191/C3561/#786743					Space reserved for Contractor																																																								
FILE No. C/PMOG/1KE/C5191/C3561/#786743																																																															

ATTN: 許元生 P.2

**HIGHWAYS DEPARTMENT****NEW TERRITORIES REGION**

2nd floor Ho Man Tin Government Offices,  
88, Chung Hui Street, Ho Man Tin, Kowloon  
Web Site: <http://www.hyd.gov.hk>

路政署


新界區

九龍何文田忠孝街 88 號  
何文田政府合署二樓

網址: <http://www.hyd.gov.hk>

[8GZ4]

本署接獲 Your Ref.: (8M17) in HNT/05/HY/06(SUB)  
來函編號 Your Ref.: CH05HY2006/TPN0121  
電 話 Tel. No.: 2762 3346  
傳真 Fax No.: 2714 5228



7 August 2007

Chiu Hing Construction & Transportation Co. Ltd  
Rm 201, Fuk Shing Commercial Building  
28 On Lok Tsuen Street, On Lok Tsuen,  
Fanling, N.T.  
(Attn: Mr. Chan Chi Wai)

Dear Sir,

Contract No. 05/HY/2006Highways Department Term Contract

(Management and Maintenance of Roads in Tai Po and Northern Districts excluding  
High Speed Road 2007-2012)

Re : Submission of Precast Concrete Paving Blocks

I refer to your above letter dated 16 July 2007 proposing the use of precast concrete paving blocks supplied by Good View Construction Materials & Engineering Co., Ltd.

I note that some of the attached test certificates are outdated and might not comply with the testing requirements set out in PS Clauses 11.78.7 to 11.78.10. I would also like to draw your attention on the submission requirement set out in PS Clause 11.68. Please re-submit your proposal as per the relevant PS Clauses.

central lab. 許元生  
PTO: Mr. Yeung Hung Pak  
23051288 許元生  
7721

Yours faithfully,

(CHENG, Siu Chung)  
Engineer's Representative  
Highways Department/NT Region

c.c. SLA1, Landscape Unit

Internal

SME/NE, SDE/NE, SDE/SD, SME/STR(NT), ME/TP, ME/N,  
ME/Slopes(E), ME/STR(NE), DE/TP, DE/N, MSIOW/NE,  
MIOW/TP, MIOW/N, MIOW/STR(NE), DIOW/TP,  
DAIOW/N(SD), MAIOW/TP&N Slopes





**水務署**  
**Water Supplies Department**

九龍灣辦事處  
Kowloon Bay Office

九龍 九龍灣 大業里十一號  
11 Tai Yip Lane, Kowloon Bay, Kowloon

電子郵件  
e-mail

電話  
Telephone 2152 5738

圖文傳真  
Facsimile 2351 6949

編號  
Reference (4) in WSD/M/7418/24/WSD/06/R20/040

By Post and Fax  
(Fax no. 2580 0697)

3 August, 2007

China Geo-Engineering Corporation  
Rms. 2421-25, 24/F,  
Sun Hung Kai Centre,  
30 Harbour Road,  
Wan Chai,  
Hong Kong.

Dear Sirs,

**Contract No. 24/WSD/06**  
**Replacement and Rehabilitation of Water Mains, Stage 2 –**  
**Mains in Sai Kung**

**Material Submission – Precast Concrete Paving Blocks**

I refer to your letter ref.: C958/SK/A2/CHS/078/07/07 dated 6 July 2007.

I have no objection to your proposal to use the precast concrete paving blocks supplied by "GoodView Construction Materials & Engineering Co., Ltd.".

Yours faithfully,

(IP Chit Ki)  
Engineer/Construction (24)

c.c.

site agent  
site office via I/C(24)

CGEC				
24/07/2007		Site Office		
Date: 23 Aug 07				
File No.: C958				
Name	Title	Info.	Action	Sign
	PD	/		
	PM	/		h
	SA	/		✓
	QS	/		ML
	SO	/		ML
	GF	/		ML
	ICE			
	ICE			
	SSA	/		ML





本函檔號:

Our Ref. HD(EM)KWH(W) 5/27/14

來函檔號:

Your Ref. EHM/04/200309785/001/003

圖文傳真: 2246 8472 / 2762 1005  
Fax.

電話: 2760 3311  
Tel.

日期: 13 December 2004  
Date

**Keung Kee Construction Limited**  
Room 29 & 31,  
2/F., Man Cheong Building,  
Ferry Point,  
Kowloon,  
Hong Kong.

Dear Sirs,

**Contract No.: 2002 0024**  
**Project: Resurfacing to existing pavement with paving blocks**  
**near Block D & Block E in Model Housing Estate**  
(Works Order No. 200309772-001)


**Material Submission**

I refer to your letter dated 15.11.2004 concerning the material submission for the captioned project. Please be informed that we have no objection to the use of the following material subject to no additional time and cost implications:-

Item	Description of Material	Supplier	Comment
1.	Precast Concrete Paving Block 200 x 100 x 80mm	Goodview Construction Materials & Engineering Co., Ltd.	Approved

However, please be reminded that such approval will never relieve from you the liabilities under the Contract and the letter will not be quoted or misused in any other Contracts or for any commercial deals in connection with your business.

Yours faithfully,

  
(Ma Ting-mo)

Maintenance Surveyor/Kowloon West and Hong Kong  
for Contract Manager

c.c. SCW/KWH  
File via MS/KWH

ACW/KWH12



2nd floor Ho Man Tin Government Offices,  
82, Chung Hwa Street, Ho Man Tin, Kowloon.

何文田政府合署二樓

本署接獲 Our Ref.: ( ) in HNT 15/HY/2003(M)

來函編號 Your Ref.: CH15HY03/TP&N132

電話 Tel. No.: 2762 4090

圖文傳真 Fax.: 2714 5228

By Fax and Post  
(Fax No. 2782 1075)

8 November, 2004

Chiu Hing Construction and Transportation Co., Ltd.  
Room 201, 2/F, Fuk Shing Commercial Building  
No. 28, On Lok Mun Street  
On Lok Tsuen  
Fanling, N.T.  
(Attn.: Contract Manager, Mr. Raymond Cheung Cheuk Lok)

Dear Sir,


Contract No. 15/HY/2003  
Highways Department Term Contract  
Tai Po and North Districts (2004-2007)

Proposed Wet Mix Paver

I refer to your above re-submission under the letter dated 3.11.2004 in connection with the proposed wet mix paver supplied by Goodview Construction Materials & Engineering Co. Ltd. for use in this Contract.

Approval is hereby given under Clause 17 of the General Conditions of Contract for Term Contracts for Civil Engineering Works (2002 Edition) for use of the above material subject to your confirmation that the colour pigments in your re-submission shall be used by the manufacturer for the production of the wet mix pavers.

Yours faithfully,

  
(W.W. TSE)

Engineer's Representative  
Highways Department/N.T. Region

Internal

ME/N  
ME/TP  
DE/N  
DE/TP  
SMIOWN2  
MI/TP  
MI/N1  
MI/N2

Orig. File #	Post	Initial	Date
1	Mr. Dk		
2	G.A.D.		
3	G.A.M.		
4	G.M.		
5	M.C.		
6	A.G.M.		
7	A.M.C.		
8	S.M.		
9	S.O.		
10	S.E.A.N.		
11	S.E.A.T.P.		
12	S.A.		
13	S.A.		
14	Goodview		
15	W.W. Tse		

RECEIVED 8/11/04

Orig. File #	222512
Notes	
Log	
Checked	
ICP Qtr	
A. 1/10	
11-11	
12-11	
13-11	
14-11	
15-11	
16-11	
17-11	
18-11	
19-11	
20-11	
21-11	
22-11	
23-11	
24-11	
25-11	
26-11	
27-11	
28-11	
29-11	
30-11	
31-11	
32-11	
33-11	
34-11	
35-11	
36-11	
37-11	
38-11	
39-11	
40-11	
41-11	
42-11	
43-11	
44-11	
45-11	
46-11	
47-11	
48-11	
49-11	
50-11	
51-11	
52-11	
53-11	
54-11	
55-11	
56-11	
57-11	
58-11	
59-11	
60-11	
61-11	
62-11	
63-11	
64-11	
65-11	
66-11	
67-11	
68-11	
69-11	
70-11	
71-11	
72-11	
73-11	
74-11	
75-11	
76-11	
77-11	
78-11	
79-11	
80-11	
81-11	
82-11	
83-11	
84-11	
85-11	
86-11	
87-11	
88-11	
89-11	
90-11	
91-11	
92-11	
93-11	
94-11	
95-11	
96-11	
97-11	
98-11	
99-11	
100-11	

TOTAL P.03

FROM : 020655R

FAX NO. : + 852 2631 7814

Feb. 16 2006 10:17AM P2/2

28-NOV-2003 10:11 FROM

TO 26317814

P.C.I



## HIGHWAYS DEPARTMENT

2nd floor Ho Man Tin Government Offices,  
18, Chung Hui Street, Ho Man Tin, Kowloon.

九龍何文田區政府辦事處  
何文田政府合署二樓

本署收 01 Ref: ( ) in HNT (HY/2001/18)/R20/720

收信日期 Your Ref: 0206/23.03/1410

電 話 Tel. No.: 2716 1043


傳 真 Fax: 2715 3573

Fax: 2872 4779

Rjc: 1+1

Barbican Construction Co Ltd  
42/F, MLC Tower,  
248 Queen's Road East,  
Wanchai, Hong Kong

HY/2001/18 SITE OFFICE



27 November

Sai Sha Road Widening Between Kam Ying Road And Future Trunk Road T7 Junction Contract No. HY/2001/18				
File no: 0206/23.03				
	Clk	Copy	Action	Initial
CH				
EM				
SA				
PL Eng				
Eng				
Sup				
POS				
S. Sur.				
Safety				
Others				
Reply Required				<input type="checkbox"/>

Dear Sirs,

Contract No. HY/2001/18  
Sai Sha Road Widening between  
Kam Ying Road and Future Trunk Road T7 Junction

Material Submission — Light Yellow Pre-cast Concrete Block Paver

I refer to your above quoted letter of 24 November 2003 submitting the samples of light yellow concrete block pavers for my comment.

As advised by my Landscape Architect (Mr. CHOW), he had no comment on the colour of the light yellow concrete block paver. In this regard, I have no comment on your proposed supplier 'Good View Construction Material Co., Ltd' to supply the 200x100x60mm light yellow concrete pavers for the construction of footpath under this Contract.

I would like to remind you that, in accordance with PS Clause 135(1), no claim for delay due to the unavailability of material from the Employer will be entertained.

Yours faithfully,

(Greg AEUNG)

Engineer's Representative  
Highways Department / NT Region W

L.E.

Site Agent (Attn: Mr. K.I. MOK) — fax: 2631 7814

SLA/2, HyD (Attn: Mr. Y.T. Chow) — fax: 2310 8438

Site Copy

YF/W/W/GL/WKKJ

V:\User\_C\SA\SH\HY2001-1\W20-730\SLB-Yellow\Proposal\Completed\other bar



HYD 18

11-2003 10:07 FROM

TO 26317814

F.01



# HIGHWAYS DEPARTMENT

2nd floor Ho Man Tin Government Offices,  
88, Chung Wai Street, Ho Man Tin, Kowloon.

九龍何文田忠孝街88號  
何文田政府合署二樓

本署編號 Our Ref.: ( ) in HNT (HY/2001/18)/R20/720

2441927

來函編號 Your Ref.: 0206/23.03/1314


電話 Tel. No. 2716 1043

傳真 Fax: 2715 3573

15 November 2003

Barbican Construction Co Ltd  
42/F, MLC Tower,  
248 Queen's Road East,  
Wanchai, Hong Kong

HY/2001/18 SITE OFFICE



Dear Sirs,

Contract No. HY/2001/18  
Sai Sha Road Widening between  
Kam Ying Road and Futara Trunk Road T7 Junction

## Material Submission--Pre-cast Concrete Block Paver

I refer to your above quoted letter of October 2003 submitting the samples of dark brown and light brown concrete block pavers for my comment.

As advised by my Landscape Architect (Mr. CHOW) in the meeting on 29 October 2003, he had no comment on the colour of the dark brown concrete block paver and rejected the color of the light brown concrete paver. In this regard, I have no comment on your proposed supplier "Good View Construction Material Co., Ltd" to supply the dark brown concrete paver only for the construction of footpath under this Contract.

Sai Sha Road Widening Between Kam Ying Road And Futara Trunk Road T7 Junction Contract No. HY/2001/18				
File no: 0206/23.03				
	Clk	Copy	Action	Initial
GM				
PM				
SA				
PL Eng				
Eng				
Sup				
POB				
Br. Sec.				
Salary				
Others				
Reply Required				<input type="checkbox"/>

Yours faithfully,

*Greg Leung*  
(Greg LEUNG)

Engineer's Representative  
Highways Department / NT Region

c.c.

Site Agent (Attn: Mr. K. IMOK) - fax: 2631 7814

SLA/2, Hyd (Attn: Mr. Y T Chow) - fax: 2310 8438

Site Copy

*K. Imok*  
YF/W/W/GL/WKK/

V:\User\_C\SLA\HY2001-18\R20-720\SA-Dark Brown Precast Concrete Paver.doc

Urgent by Fax and Post

23568386



**HIGHWAYS DEPARTMENT  
HIGHWAYS (KOWLOON) REGION**

13/F, Nan Fung Commercial Centre, 19 Lam Lok Street,  
Kowloon Bay, Kowloon  
Web site: www.hyd.gov.hk

Doc No: SO-000031-675  
[HI-013888-311]

本署檔號 Our Ref.: (3M9P)KH07/HY/2001(MAT)(M4)  
來函檔號 Your Ref.: J2842/HYD0592/03  
電話 Tel. No.: 2707 7474  
圖文傳真 Fax No.: 2758 3394

→ Gammon Skanska Limited  
28/F Devon House  
TaiKoo Place 979 King's Road  
Hong Kong  
(Attn: Mr. Perry WONG)

Dear Sirs,

路政署  
(九龍區)

九龍灣臨樂街十九號  
南豐商業中心十三樓  
網址: www.hyd.gov.hk

GSL - 2842		
Date	7/7/2003	IN/OUT
File Index	302, J113 (1)	
Distribution	Info	Action
CC		
CM	✓	
DCM(A)		
DCM(W)	✓	
SSA(A)	✓	
SSA(W)		
SO		
MC		
QS		
	✓	
Copy to		

26 June 2003

Contract No.: 07/HY/2001  
Highways Department Term Contract  
(Wong Tai Sin and Kwun Tong Districts 2002 - 2005)

Works Order No. BA058414-3  
Determination of Water Absorption of Clay Pavers - Austral

I refer to your letter dated 6.6.2003 regarding an increase by 1% in the water absorption value for the "Austral" clay paver products with reference to Note 9 of Drawing No. RD/PED/02A

Please be advised that our Landscape Unit considers water absorption value of "Austral" clay paver products used in the captioned Works Order at Junction Road as follows:

- (i) Red coloured clay paver (SuZhou) - Should meet the minimum water absorption value.
- (ii) Dark grey coloured clay paver (Yu Men) - 1% increase in the water absorption value is satisfactory.

In view of the above, you are hereby required to submit your remedial proposal for the clay pavers that water absorption values fail to comply with the requirement of Contract

Yours faithfully,

(Y K NG)

for Chief Highway Engineer/Kowloon  
Highways Department

FROM : J2701

FAX NO. :

May. 15 2002 03:29PM R2  
RECEIVED

15-MAY-2002 15:00

1052 2796 4090

1.5 MAY 2002

**Urgent by Fax and Post**  
**2356 8386**



**HIGHWAYS DEPARTMENT  
HIGHWAYS (KOWLOON) REGION**

11/F., Nan Fung Commercial Centre, 19 Lam Lok Street,  
Kowloon Bay, Kowloon

Doc No: SO-000013-029  
[ HI-004335-003 ]

本署編號 Our Ref.: (197A)KH07/HY/2001(MAT)(M9)  
來函編號 Your Ref.: J2842/HYD0043/02 & J2842/HYD0064/02 & J2842/HYD0036/02  
電話 Tel. No.: 2707 7437  
圖文傳真 Fax No.: 2758 3394

路政署  
(九龍區)  
九龍灣臨樂街十九號  
南豐商業中心十三樓

15 May 2002

Gammon Skanska Ltd.  
28/F Devon House  
TaiKoo Place 979 King's Road  
Hong Kong  
Attn: Mr. H S KO



Dear Sirs,

**Contract No. 07/HY/2001**  
**Highways Department Term Contract**  
**Wong Tai Sin and Kwun Tong Districts (2002-2005)**

## Clay Pavers

I refer to your above letters dated 25 April 2002, 7 May 2002, and 22 April 2002 respectively proposing the use of clay pavers and have no objection to the use of the following products in the Contract :

<u>Brand Name</u>	<u>Size</u>	<u>Supplier</u>
Austral	200x100x65mm	LTD (Australia) ✓
Austral	200x100x50mm	LTD (Australia) ✓

The following products are rejected as their sizes are uncommon in footway construction.

<u>Brand Name</u>	<u>Size</u>	<u>Supplier</u>
Austral	230x114x65mm	The Austral Brick Company PTY.
Austral	230x114x50mm	The Austral Brick Company PTY
PHG	230x114x65mm	CSR Building Materials Export Group (Australia)
PHG	230x114x65mm	CSR Building Materials Export Group (Australia)
Claypave	230x115x50mm	Luenik Construction Material Co., Ltd.

GSL - 2842			
site		IN/OUT	
file index			
simulation	info	Action	
O			
M	(R)		
CMVA			
CMVA	WVA		
DATA	WVA		
SAVO	(R)		
O			
IC			
S			
copy to			

Attn: Mr. Danny Hui

Fax: 28 12 4179

From: CRBC



香港房屋委員會

Hong Kong Housing Authority

Our Ref.: HD(CE) 518/109/11

Tel No. : 2274 4155

Fax No. : 2274 4329

Date : 21 March 2002

China Road and Bridge Corp.  
26/F, Golden Centre,  
188 Des Voeux Road,  
Central, Hong Kong.

(Attention: Mr. Raymond Mau)

Dear Sir,

HKHA Contract No. 142 of 1998  
Road and Drainage Works for Tiu Keng Leng  
Precast Concrete Paving Blocks

Road & Drainage Works for Tiu Keng Leng				
No.: (H) CRBC/HA142/S210(4)/328				
Date: 21 MAR 2002				
	Action	C.C.	Encl.	
PM		/		
SA		/		
QCE		/		
CE				
CE				
QS				
LS		/		
GF		/		
FM		/		
SD				
ED				

I refer to your letter ref. (out) CRBC/HA142/S210(4)/328 dated 18 March 2002 in which you proposed the hazard warning blocks and precast concrete paving blocks (red colour) to be supplied by Good View Construction Materials Co., Ltd.

Having reviewed your submitted samples and the booklet, I have no objection to your proposal provided that you confirm that the thickness of hazard warning blocks provided should be 60 mm instead of 50 mm as shown in the booklet.

Yours faithfully,

(Terence Kwan)  
Civil Engineer/22  
Contract Manager's Representative

c.c. : PQS (Davis Langdon & Seah HK Ltd.) (Attn. : Mr. Nelson Lee)  
Site  
File copy via SCE/2

TK/AP/cw  
1020321a

HD 111

香港九龍何文田佛光街 33 號房屋委員會總辦事處

Housing Authority Headquarters, 33, Fat Kwong Street, Ho Man Tin, Kowloon, Hong Kong.






RECEIVED  
25 JAN 2002  
HIGHWAYS MEMO

From: Landscape Architect/HK, Highways Dept.	To: Chief Highway Engineer, Hong Kong/HyD
Ref: _____ in HYDT 12/5/HK-E	(Attn.: Mr. Mr. K.S. Tam)
Tel. No: 2370 2861 Fax. No. 2310 8438	Your Ref: ( ) in H13(MNP)
Date: 21 January 2002 Email lahk.lu@hyd.gov.hk	Dated: 10.1.2002

Paving Pattern for Footpath in Healthy Street East, Healthy Street Central,  
Healthy Street West and Tin Chiu Street

I refer to your MUR and our (Tam/Chan) subsequent teleconversation

2. I have no adverse comment on your proposed wet-mix block in herringbone pattern for the captioned area to match with that of the Tsat Tsz Mui Road. The colour of the blocks is proposed to be mid-brown to distinguished from the red block at Tsat Tze Mui Road. In order to minimize the need for cutting and wastage, the 90° herringbones is preferred.
3. It is learned that the current paving along King's Road will be replaced by red clay bricks. Attached please find a marked-up plan to illustrate transition between the two re-paving works. Please liaise with the project engineer for King's Road re-surfacing for a logical transition. Please also note the provision of matching covers for utility openings and tactile tile at apron of pedestrian crossing according to the current standard.
4. I should be grateful if you could ask your contractor to submit sample of the brown wet-mix block before laying.

  
(CHAN Wai-keung, Eric)  
Landscape Architect/Hong Kong  
Landscape Unit, Highways Department

3

中環區市政局  
來函編號 YOUR REF P178/1052  
電話 TELEPHONE 2231 5800  
傳真 FAX NO. 2576 8244

12 November 2001

Hung Mau Realty and Construction Ltd.  
Room 18, 5/F., Pacific Trade Centre  
2 Kai Hing Road, Kowloon Bay  
Kowloon, Hong Kong

(Attn: Mr. KONG Chuck-yui, Howard)

Dear Sir,

Contract No. 10/HY/1999  
Highways Department Term Contract  
(Eastern and Southern Districts of Hong Kong Island 2000-2003)

Wet-mix Precast Concrete Paving Block  
by Good View Construction Materials Co. Ltd.

I refer to your letter dated 5 November 2001 proposing the use of wet-mix precast concrete paving blocks manufactured by "Good View Construction Materials Co. Ltd." under this Contract.

Having examined the submitted details, I have no objection to your use of the wet-mix precast concrete paving blocks of sizes 200mm x 100mm x 80mm and 200mm x 100mm x 60mm manufactured by the said company in this Contract. Moreover, you are reminded to observe the requirements of General Specification (GS) Clauses 11.75, 11.76, 11.77 and 11.78 regarding testing of the paving blocks and to provide test results for our vetting in accordance with GS Appendix 11.1.

Yours faithfully,

(NG Tak-wing)  
The Engineer for the Contract  
Hong Kong Regional Office  
Highways Department



KST/owc

TOTAL P.01



# **HIGHWAYS DEPARTMENT HIGHWAYS (HONG KONG) REGION**

7/F. & 8/F. NORTH POINT GOVERNMENT OFFICES BUILDING,  
333 JAVA ROAD, NORTH POINT, HONG KONG.

路政署

港島區

北角政府大樓 333 號  
北角政府合署七樓及八樓

本署編號 OUR REF. ( ) in HH 20/10/HY/1999 (MSW)  
來函編號 YOUR REF. P178/1504 & /1534  
電話 TELEPHONE 2231 5800  
圖文傳真 FAX NO. 2576 6244

*Handwritten:* Fax to Score Alan Kwong 22/10/2001  
2 Nai Yuen Hwy Mr. J. Ma 25/10/2001

18 October 2001

**BY FAX**

(Fax No. 2896 7144)

Hung Mau Realty and Construction Ltd.  
Room 18, 5/F., Pacific Trade Centre,  
2 Kai Hing Road, Kowloon Bay,  
Kowloon, Hong Kong.

Attn.: Mr. KONG Chuck Yui

Dear Sir,

**Contract No: 10/HY/1999**  
**Highways Department Term Contract**  
**(Eastern and Southern Districts of Hong Kong Island 2000 - 2003)**

## Proposed Clay Paver

I refer to your above letters dated 3 & 11 October 2001 proposing the use of the below listed clay pavers for this Contract:

	<u>Name of Product</u>	<u>Supplier</u>
1.	Nubuk	Pioneer Building Product
2.	PGH	CSR Building Materials Export Group (Australia)
3.	Austral	The Austral brick Company PTY, LTD (Australia)
4.	Selkirk	Selkirk Brick Pty. Ltd

With reference to your submitted documents, I have no objection to your use of these materials in this Contract. I shall however remind you that there are variations in quality of products of the same brand name. You should ensure that only the product conforming to our specification would be used in the Contract.

Thank you for your attention.

Yours sincerely,

(Raymond, W.F. Ho)  
The Engineer for the Contract  
Chief Highways Engineer/Hong Kong  
Hong Kong Regional Office  
Highways Department

WHC/whc

CHATWIN ENGINEERING LIMITED  
Room 1701-1702, 17/F., Paliburg Plaza,  
68 Yee Wo Street, Causeway Bay, Hong Kong

Tel: (852) 2882-8232  
Fax: (852) 2882-8380

FACSIMILE TRANSMISSION

Our Ref.: HKS5020/FX/056/01 Fax No.: 28724779  
To: Goodview Date: 31-8-01  
Attn.: 許生 Total Pages: 2  
From: CHRIS TAM (including this page)

If you do not receive all pages, please telephone or telecopy immediately.

Re: MTRC Hong Kong Station Carpark Work  
Contract No. 5020

MTRC's approval on Precast Concrete Pavier Block

Attached please find the MTRC's Engineer Approval on your proposed precast concrete pavier block for your information & attention.

Best regards,  
*Chris*

C.C. YIP, C.W. Cheng (Procurement Dept.)  
Ms. Emily Ng (Q.S.)

**MTR CORPORATION LIMITED**  
**CONTRACT 5020 – HONG KONG CARPAI WORKS**  
**ENGINEER'S RESPONSE FORM**



FROM : ENGINEER'S REPRESENTATIVE CONTRACT 5020 MTR CORPORATION LIMITED HONG KONG	TO : Shun Hing – Sanki JV Limited 16/F., Shun Hing Centre 8 Shing Yiu Street Kwai Chung N.T. ATTN : MR. K. C. Ma - Project Manager	ERF NO : CSF/5020/MAT/ABWF/0005b
		SIGNED : <i>[Signature]</i> Raymond T'ang (SConE)
		DATE : 30 Aug 2001

DOCUMENT TITLE	DOCUMENT NO. & DATE SUBMITTED	ENGINEER'S COMMENTS	STATUS*	RE-SUBMISSION REQUIRED YES/NO
MATERIAL SUBMISSION Precast Concrete Pavement Block Size: 200 x 100 x 80mm, Colour: Light Grey & Dark Grey Precast Concrete Pavement Block (Code ST-28 & 29) (for Road Pavement) Good View Construction Materials Company	24 August 2001	No adverse comment on your submitted compliance certificate. Please carry out the quality check on the pavior blocks to make sure the dimensions and colour of concrete blocks, to be complied with M&W Specification Clause 17.62 prior to the delivery.	Approved	No

REGISTRATION	INTERNAL DISTRIBUTION		EXTERNAL DISTRIBUTION	
TS Receipt date : .....				
TS Registration No : .....				

CHATWIN ENGINEERING LIMITED  
Room 1701-1702, 17/F., Paliburg Plaza,  
68 Yee Wo Street, Causeway Bay, Hong Kong

Tel: (852) 2882-8232  
Fax: (852) 2882-8380

FACSIMILE TRANSMISSION

Our Ref.: HKS5020/FX/029/01 Fax No.: 28724779  
To: Good View Date: 1-8-2001  
Attn.: Mr. Danny Hui Total Pages: 2  
From: Chris Tam (including this page)

If you do not receive all pages, please telephone or telecopy immediately.


Re: MTRC Hong Kong Station Carpark Work  
Contract No. 5020

MTRC's comment on Precast Concrete Pavement Block

Attached please find the MTRC's comment on your proposed precast concrete pavement block for your further action. Should you have any query, please feel free to contact the undersigned at tel 28957579

Best Regards,  
C. S. Tam

C.C. Mr. C.W. Cheng (Procurement Dept.)  
Mrs. Emily Ng (Q.S.)

<b>FROM: ENGINEER'S REPRESENTATIVE</b> CONTRACT 5020 MTR CORPORATION LIMITED HONG KONG		<b>TO:</b> Shun Hing - Sanki JV Limited 16/F., Shun Hing Centre 8 Shing Yiu Street Kwai Chung N.T. <b>ATTN:</b> MR. K. C. Ma - Project Manager		<b>REF NO :</b> CSF/5020/MAT/ABWTF/0005A	
		<b>SIGNED :</b>  Raymond Tang (SConE)			
		<b>DATE :</b> 21 July 2001			
<b>DOCUMENT TITLE</b>	<b>DOCUMENT NO. &amp; DATE SUBMITTED</b>	<b>ENGINEER'S COMMENTS</b>		<b>STATUS</b>	<b>RE-SUBMISSION REQUIRED YES/NO</b>
<b>MATERIAL SUBMISSION</b> Precast Concrete Pavement Block Size: 200 x 100 x 80mm, Colour: Light Grey (Precast Concrete Pavement Block (Code SP-29) for Road Pavement) - Good View Construction Materials Company	19 July 2001	Sample (Light Grey - S129) to be submitted for my further comment/record. Remark Please confirm whether the concrete pavements (Dark Grey - S128) to be supplied by the same supplier. If yes, please make the submission for the formal approval.		Approved in Principle	Yes For Sample
<b>REGISTRATION</b>		<b>INTERNAL DISTRIBUTION</b>		<b>EXTERNAL DISTRIBUTION</b>	
CRS Receipt date					
CRS Registration No					

\* STATUS - APPROVED/APPROVED SUBJECT TO INCORPORATION OF COMMENTS NOT-APPROVED IN PRINCIPLE/NOT APPROVED (To be completed as applicable)



水務署

Water Supplies Department



電子郵遞  
e-mail

電話  
Telephone 2152 5761

檔號  
Reference (5) in WSD/M7296/7/WSD/00/R20/300

圖文傳真  
Facsimile 2351 6949

10 July 2001

U-Tech Engineering Co., Ltd.

6/F, 100 To Kwa Wan Road  
Kowloon, Hong Kong

Dear Sirs,

**Contract No. 7/WSD/00  
Replacement of Water Mains in  
Tai Po Market and Tai Po Tau Shui Wai**

**Precast Concrete Unit, Paving Block and Brickwork**

I refer to your letter ref. UT/A18/01/1012 dated 28 June 2001 proposing the material supplier – Good View Construction Material Company for the precast concrete unit, paving block and brickwork for the captioned Contract.

I have no objection to your proposed materials supplied by Good View Construction Material Company.

According to Clause 16.21(2) of the General Specification (GS), you are reminded that the required certificates shall be submitted for each batch of precast concrete units delivered to the Site.

In addition, you are reminded that the color of the paving block shall be consistent over the area to be paved as stipulated in Clause 11.61(6) of the GS.

Yours faithfully,

(KU Kwok Pun)  
Engineer / Construction (20)

c.c. | Site Agent thro' I/C – M.Y. Ma  
WSD Site Office thro' I/C – M.Y. Ma

九龍東分署  
Mainland South East Regional Office  
九龍觀塘偉業街六十五號  
水務署九龍東區大樓  
WSD Kowloon East Regional Building,  
65 Wai Yip Street, Kwun Tong, Kowloon

供水百五年 服務客為先

150 Years of Water Supply

Customer Care First



**CASTCO**

**CASTCO TESTING CENTRE LTD.**

Test Certificate

Determination of skid resistance value

for clay and calcium silicate pavers

(Based on BS6677 : Part 1 : 1986 Appendix E)

Date of issue: 28 April 2001

Page 1 of 1 page(s)

Castco LRN: NW/MISCEI. 210428-1

Details as supplied by client

Client: Good View Construction Materials Co.

Client's ref. no.: --

Contract no.: D/MTRC/TKE/604

Job title: --

Grade: 20/20

Work size : 300mm x 300mm (L x W)

Laboratory Test Result

Date sample received : 28 April 2001

Date of test : 28 April 2001

Specimen No.	Wet skid resistance value	Mean wet skid resistance value
1	100.6	99.2
2	96.2	
3	98.0	
4	104.6	
5	96.6	

Remark : Test result relates only to the specimen tested.

Checked by:

K. K. Ho

Certified by:

KEITH CHOI  
B.Sc., MBA, MHKIE

Form No. NI\_6677 SRV (Edition: 2000)