



Our Ref. : HD(MB)CE 3/388/109/11
Your Ref. : HA20070055/HD/0139 dd 29Dec08
Tel.: 2761 6991
Fax.: 2761 7300

Date : 6 January 2009

Harvest Civil Engineering Co. Ltd.,
Rm. 1005, 10/F Shing Chuen Ind. Bldg.,
25-27 Shing Wan Road,
Tai Wai, Shatin.

(Attn: Mr. Patrick M.Y. Chung – Site Agent)

Dear Sirs,

Contract No. 20070055
Civil Engineering Improvement Works at Kai Yip Estate
Material Submission – Paving Blocks

I refer to your letter ref. HA20070055/HD/0139 dated 29 December 2008 regarding the above-mentioned proposal.

I have no objection to your proposal of appointing "Goodview Construction Materials and Engineering Co., Ltd." as your supplier for paving blocks for this contract. Please note that your submitted paving block should be used in footways only but not in Emergency Vehicular Access (EVA) area.

Yours faithfully,

(Eva Y.W. MAK)
Civil Engineer 6/M
Contract Manager's Representative

c.c. PQS - Franklin and Andrews (Hong Kong) Ltd. (Attn : Mr. Y.W.)
Site - IOW/M, CSEG/74
File via SCE/M

