

ENGINEER'S OFFICE
BLACK & VEATCH
HONG KONG LTD.



ENGINEER'S
REPRESENTATIVE'S
OFFICE

25/F., Millennium City 6
392 Kwun Tong Road
Kowloon, Hong Kong
Tel.: 2601 1000
Fax: 2601 3988

Water Supplies Department
Agreement No. CE 10/2008

Suite C, 4/F,
Young Ya Industrial Building.,
381-389 Sha Tsui Road.,
Tsuen Wan, N.T.,
Tel.: 3568 2765
Fax: 3568 2702

Your ref. : 1054/J1/S108
Our ref. : 4977/(11/WSD/11)/M25/120-0245

16 May 2012

Pollard-CNCEC Joint Venture
Unit 503, Citimark Plaza,
28 Yuen Shun Circuit,
Sha Tin, New Territories

Attn: Warren Tse (Site Agent)

Dear Sirs,

RECEIVED
21 MAY 2012

BY:

Contract No. 11/WSD/11
Replacement and Rehabilitation of Water Mains,
Stage 4 Phase 2 – Mains in Tsuen Wan and Kwai Tsing
Material Submission – Precast Concrete Unit (Supplied by GoodView Construction
Material & Engineering Co., Ltd.)

I have no objection in principle to your proposed Precast Concrete Unit to be supplied by GoodView Construction Material & Engineering Co., Ltd., subject to the comments listed overleaf. Please provide the outstanding information as soon as possible.

Please be reminded that certificates shall be submitted for each batch of precast concrete units delivered to the Site as in accordance with G.S. 16.21(2). Furthermore, the colour of paving block shall be consistent over the area to be paved as stipulated in G.S. 11.61(3).

Yours faithfully,


Mason Pau
Chief Resident Engineer

Encl.

c.c. B&V

(Attn.: Mr. Stephanus Shou)

Reply Required: Y / N

Reply Due Date: ASAP

MP/WL/PY/GS/rt

Pollard - CNCEC JV			
Project No.: 11/WSD/11			
Title	Inf.	Act.	Signature
PM			
APM			
SA			
Sub-A			
SE-E			
AE			
Site-O			
GF			
RSO			
TM			
Filing NO.:			