



The Government of the HKSAR  
Drainage Services Department



**BLACK & VEATCH**  
Building a world of difference®

ENGINEER'S REPRESENTATIVE'S OFFICE :  
38 On Kui Street, Fanling, New Territories Tel: 2676 9292 Fax: 2676 9983

Your ref. : ZH/DC/2007/02/1.1/BV/4842&4866  
Our ref. : 2486/DC/2007/02/R20/300 - 4209

Date: 2 September 2010

Zhuhai International Economic & Technical Cooperation Corporation  
Flat 1102, 11/F, Yardley Commercial Building,  
3 Connaught Road West,  
Sheung Wan,  
Hong Kong

Attn: Mr. Tommy Mok

Dear Sirs

RECEIVED  
02 SEP 2010  
BY: \_\_\_\_\_

Contract No. DC/2007/02  
Drainage Improvement Works in Lung Yeuk Tau, Kwan Tei South and Leng Tsai, Fanling  
Material Submission No 206  
GoodView's Precast Grassed Cellular Concrete Paving

I refer to your letters dated 18 August 2010 and 25 August 2010 and subsequent discussions regarding the above subject.

Pursuant to PS27.03, I have no objection on your proposal to adopt GoodView Construction Materials & Engineering Co. Ltd (with products manufactured by Jian Zheng Building Material Manufacturer of Zhongshan City) as the supplier of precast concrete cellular concrete paving for construction under this Contract, subject to satisfactory performance on site.

You are requested to submit the movement joint details and the result of test of compressive strength of concrete in accordance with PS 27.03 (13) & (14) and PS 27.03 (9) respectively. You are also required to arrange the factory visit of Jian Zheng Building Material Manufacturer for our inspection of manufacturing of precast grassed cellular concrete paving in accordance with GCC clause 42.

Yours faithfully,

C.L. Leung  
ENGINEER'S REPRESENTATIVE

CLL/KL/rc

c. c. B&V - Attn: Mr. E. K. I. Lo