

**HIGHWAYS DEPARTMENT****URBAN REGION**

7-8 FLOORS, NORTH POINT GOVERNMENT OFFICES BUILDING  
333 JAVA ROAD NORTH POINT HONG KONG  
Web Site: <http://www.hyd.gov.hk>

Urgent by Fax  
(2609 4225)

**路政署****市區**

北角匯豐道333號  
北角政府合署7-8樓  
網址: <http://www.hyd.gov.hk>

1 1

本署編號 Our Ref.: (0A6F)HH HY/2003/07/M/MISC(SDHW)  
來函編號 Your Ref.: WY/HY/2003/07/M04/160  
電話 Tel. No.: 2231 5617  
圖文傳真 Fax No.: 2576 6244

12 July, 2004

Wui Yip Civil Engineering Limited  
Unit 8, 6/F, Shing Chuen Ind. Bldg.,  
25-27 Shing Wan Road,  
Shatin, NT

(Attn: Mr. Eddie CHENG)

Dear Sirs,

**Contract No. HY/2003/07**  
**Sheung Wan Streetscape Enhancement**  
**Proposed Precast Concrete Kerbs**

I refer to your above letter dated 26 June 2004 responding to my previous letter ref. (078EM) HH HY/2003/07/M/MISC(DHWP) dated 15 June 2004 and submitting an updated test certificate for the proposed precast concrete kerbs. I have no in-principle objection to your proposal of "Good View Construction Materials Ltd." to be the supplier for precast concrete kerbs to be used under the above contract.

Your attention is drawn to Clause GS 16.21(2) that certificates shall be submitted for each batch of precast concrete units delivered to the Site.

Yours faithfully,

  
(K.C. SIU)

The Engineer for the Contract Senior District  
Engineer/HK North & West  
Highways Department, Urban Region

c.c. Site Agent - By Fax (2148 1026)

**Internal**

DAIOW/HNW(P) - WY's letters (04Q8) &amp; (08XR) refer.

WKC/KCS/wkz

| Rec'd on 13-7-04 |        |        |      |
|------------------|--------|--------|------|
|                  | Inform | Action | Copy |
| PM               |        |        |      |
| SA               |        |        |      |
| QS               |        |        |      |
| GR               |        |        |      |
| SE               |        |        |      |
| IS               |        |        |      |
| Sub              |        |        |      |



TATA P.01