



水務署
Water Supplies Department
九龍灣辦事處
Kowloon Bay Office

九龍 九龍灣 大棠里十一號
11 Tai Yip Lane, Kowloon Bay, Kowloon

電子郵件
e-mail

電話 2152 5742
Telephone

傳真
Reference

圖文傳真 2351 6949
Facsimile

(44) in WSD/M/7423/12/WSD/07/M25/110 Pt. 2

By Fax (22831689) and Post

23 JAN 2009

LETTER OUT

No. 190

23 January 2009.

China Road and Bridge Corporation
Units 1805 - 10, 18/F, K. Wah Centre
191 Java Road
North Point
Hong Kong

Dear Sirs,

Contract No. 12/WSD/07

Construction of Sha Tin Seafront No. 2 Salt Water Pumping Station and
Associated Mainlaying

Precast Concrete Product

I refer to your letters ref. (out)CRBC/12WSD07/S210(4)/004,
(out)CRBC/12WSD07/S210(4)/036 and (out)CRBC/12WSD07/S210(4)/047 dated 22.9.2008,
11.12.2008 and 13.1.2009 respectively and various discussions between your Site Engineer Mr.
T.T. Wong and our Mr. Joe Lam.

I have no objection in principle to your proposed Precast Concrete Kerbs, Trench
Covers, Precast Concrete Strips for WSD Chambers, Gullies and Paving Blocks supplied by
Good View Construction Materials & Eng. Co., Ltd., provided that the materials are in full
compliance with Contract requirements.

Pursuant to GS Clause 16.21(2), you are required to submit certificates for each
batch of precast concrete units delivered to the Site. Furthermore, you are reminded that the
colour of paving block shall be consistent over the area to be paved, stable and fade resistant
under any outdoor climate situations as stipulated in GS Clause 11.61(3).

Yours faithfully,

(WONG Cheuk To)
Engineer/Construction(18)

c.c. Site Office via I/C - Mr. K.C. HO
Site Agent

Cir. CE/C SE/C(3) CEG/C(18) E/C(18)

China Road & Bridge Corporation Contract No. 12/WSD/07			
Position	Info.	Action	Remark
Project Manager	/		
Site Agent	/		
Engineer	/		
G. Foreman			
Material Surveyor			
QS			
Safety Officer			
Head Office			

