



**HIGHWAYS DEPARTMENT**  
**URBAN REGION (KOWLOON)**

13<sup>TH</sup> FLOOR, NAN FUNG COMMERCIAL CENTRE  
19 LAM LOK STREET, KOWLOON BAY, KOWLOON  
Web site : <http://www.hyd.gov.hk>

28913834

路政署  
市區(九龍)

九龍灣臨樂街119號  
南豐商業中心十三樓

網址：<http://www.hyd.gov.hk>

RECEIVED DATE: 2013-08-01		PRT JOB NO.: 4622	
<input type="checkbox"/> Client <input type="checkbox"/> Consultant <input type="checkbox"/> Contractor <input type="checkbox"/> Govt <input type="checkbox"/> Other			
REP PRG NO.	ACT DT	DTY	CD
101	2013-08-01	101	1
Job	Mobile Com	Trng	Trng
Action By	Del: 2013-08-01	Letter	Email

本署格號 Our Ref.: (KKLEA)HyD UK/13-5/KIL11202(DHH)  
來函格號 Your Ref.: 4622/2/177/pc  
電話 Tci. No.: 2707 7411  
圖文傳真 Fax No.: 2758 3394

31 July 2013

**P&T Architects and Engineers Ltd**  
33/F, 633 King's Road,  
Hong Kong  
(Attn.: Mr. Joel CHAN)

**Dear Sirs/Madams,**

**The Open University of Hong Kong**  
**Chung Hau Street Campus Development Project - Green Area**  
**Our Ref : 4622/2/079/pc**

We refer to your letter dated 24 June 2013 and please be advised that we have no further comments to the proposed paving material.

Please note that cement and sand bedding shall be adopted in the paving block laying works.

Yours faithfully,

(Simon C C KWOK)  
for Chief Highway Engineer/Kowloon  
Highways Department

### **Distribution**

**C.C.**

**Internal**

СТО/КС

**c.c. to file**

