



**HOUSING DEPARTMENT  
ESTATE MANAGEMENT DIVISION (BUILDING WORKS)**

**MATERIAL AND SAMPLE SUBMISSION AND APPROVAL FORM**

**Part III (For Contract Manager or Contract Manager's Representative Use)**

Our Ref. No. : HD 3-4/TNS/BW/3/7/STA

Contractor's Ref. No. : 20100038/MAT/721 (ST-3-113) (1-6)

To : New Hopes Construction Co., Ltd.

Attention : Mr. LI Chi-hang, Brendan (Quality Manager)

Based on the Part I & II information, the following material(s)/sample(s):-

\*is / are approved

\*comment

1. 200x100x60mm thick pre-cast concrete paving block/Goodview//Goodview Construction Materials Co., Ltd./China	According to P.S. 18.65, contractor requires for sample testing: the sample testing shall be one block selected at random from every 200 blocks in each batch
2. Emulsion paint for Internal, 0100 series/Flower Premium Emulsion Paint/China Paint/China	Nil
3. Wall sealer (Internal use)(water base); model 971/ Flower WB acrylic masonry sealer/China Paint/China	Nil
4. Synthetic paint for wood & metal; 1200 series/Flower premium synthetic paint/China Paint/China	Nil
5. Metal primer for galv. iron (water base); model 981/ Flower water anti-corrosive primer 981/China Paint/China	Nil

\*is / are not approved

\*because

25mm wide venetian blind/Sun-factors/Sun-Factors (Manufacture) Co., Ltd./China	Neither Specification nor sample submitted.
--	---

*\*This approval shall not relieve you from your liability under the Contract.*

~~YUNG Ping-tat, Jimmy~~

Maintenance Surveyor/ Tseung Kwan O

Date : 4.8.2013

c.c. SCW/TKO, CW/TKO1, ACW/TKO14

\* Delete if inappropriate