

MTR CORPORATION LIMITED
TSEUNG KWAN O EXTENSION
CONTRACT 601 - HANG HAU STATION & TUNNELS
ENGINEER'S RESPONSE FORM



FROM : CONSTRUCTION MANAGER CONTRACT 601 MTR CORPORATION HONG KONG		TO : DRAGAGES ET TRAVAUX PUBLICS (DTP) MSF/601/ABWF/356		ERF NO : 601/ERF/ABWF/356-1 (#459315)	SIGNED : <u>A. - 2 - 2 - 2 - 0</u>	DATE : 16 October 2000
DOCUMENT TITLE	DOCUMENT NO. & DATE SUBMITTED	ENGINEER'S COMMENTS		STATUS	RE-SUBMISSION REQUIRED YES/NO	Approved in Principle
TIS - 30mm concrete roof tile supplied by Good View Construction Materials Ltd.	MSF/601/ABWF/356 dated 11/10/00 PR/P12/60023/A	No adverse comments on the sample. Further information on the tile constituents and on-efficient of slip resistance under wet and dry conditions are to be submitted for approval.		DTP MTR 601 Project Date 10 Oct 2000 Reg. No.: Filing: <input type="checkbox"/> Action Info RSC <input checked="" type="checkbox"/> JES <input type="checkbox"/> PCA <input type="checkbox"/> BIA <input type="checkbox"/> VIA <input type="checkbox"/> RBDR <input type="checkbox"/> ICM <input type="checkbox"/> IPC <input type="checkbox"/> KTC <input type="checkbox"/> HBC <input type="checkbox"/> SPa <input type="checkbox"/> DXP <input type="checkbox"/> JPA <input checked="" type="checkbox"/>	YCS	
REGISTRATION	INTERNAL DISTRIBUTION		EXTERNAL DISTRIBUTION			
	CE1 (SY) → CEII (TL) → PE (RL) → ConA (TKL) → File		ConE (KSL) → ConE (AC) → SLOW - (NW)		STATUS - APPROVED/APPROVED SUBJECT TO INCORPORATION OF COMMENTS NOTED/NOT APPROVED (To be completed as appropriate)	
EDMS Receipt date	12/10/00					4520/04/A2 DS/PAW
EDMS Registration No	00459194					cc: MSEE, DC, SCON, ASMM, PBU