



Web site 網址: <http://www.cedd.gov.hk>
 E-mail 電子郵件: bernardwoleung@cedd.gov.hk
 Telephone 電話: (852) 2762 5325
 Facsimile 傳真: (852) 2714 0079
 Our reference 本署編號: (CS) in LW/(CV/2006/01)/M2S/110 PC.3
 Your reference 來函編號: CSHK/CAZ/C&F/0032/B

MSF

土木工程處
Civil Engineering Office

000417

香港九龍公主道 101 號
土木工程拓展署大樓
Civil Engineering and Development Building,
101 Princess Margaret Road,
Kowloon, Hong Kong

11 June 2008

By Fax
(Fax no.: 2865 5229)



China State Construction Engineering (Hong Kong) Ltd
29/F., China Overseas Building
139 Hennessy Road
Hong Kong
(Attn.: Mr. Ernest Yeung)

Dear Sirs,

Contract No. CV/2006/01
Ping Ha Road Improvement Works (Ha Tsuen Section)

Material Submission
Concrete Paving Block and Precast Concrete Kerb

I refer to your submission referenced above dated 19 May 2008.

Concrete Paving Block

I have the following comments:

- i) Pursuant to GS Clause 11.68(1)(b), please submit a certificate from the manufacturer showing the particle size distribution of the aggregates; and
- ii) Referring to PS Clause 11.65A(3), please clarify with the manufacturer whether there is a shortage of supply of recycled aggregates so that we may consider their proposal for the use of virgin aggregates in lieu of recycled aggregates.

Precast Concrete Kerb

I have no objection to your proposal of using the precast concrete kerb (Type K1) manufactured by "Goodview Construction Materials & Eng. Co. Ltd" for the above Contract.

Yours faithfully,

(LEUNG Wah-on)
Engineer's Representative
Land Works Division

Civil Engineering and Development Department

CHINA STATE CONSTRUCTION ENGINEERING (H.K.) LTD	
CV/2006/01	MR. ERNST YEUNG
RECEIVED	13 JUN 2008
ENR	
AGENT	
SUPERVISOR	
ENG	
SURVEY	
POS	
1. SUPERVISOR	
2. SUPERVISOR	
ENV	
DA	

