



Bid Document

| Bid Details | | | |
|---------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| Bid End Date/Time | 17-08-2021 14:00:00 | | |
| Bid Opening Date/Time | 17-08-2021 14:30:00 | | |
| Bid Life Cycle (From Publish Date) | 90 (Days) | | |
| Bid Offer Validity (From End Date) | 65 (Days) | | |
| Ministry/State Name | Ministry Of Defence | | |
| Department Name | Department Of Defence Production | | |
| Organisation Name | Indian Ordnance Factories | | |
| Office Name | ****** | | |
| Total Quantity | 1000 | | |
| Item Category | Power Cable For Direct Burial Xlpe Ugac Cable-IS: 10418 | | |
| MSE Exemption for Years of Experience and Turnover | No No | | |
| Startup Exemption for Years of Experience and Turnover | No | | |
| Document required from seller | Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer | | |
| Bid to RA enabled | Yes | | |
| Time allowed for Technical Clarifications during technical evaluation | 2 Days | | |
| Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No | | |
| Evaluation Method | Total value wise evaluation | | |
| | A | | |

EMD Detail

| Required No | Required | No |
|---------------|----------|----|
|---------------|----------|----|

ePBG Detail

| Advisory Bank | State Bank of India |
|-------------------------------------|---------------------|
| ePBG Percentage(%) | 3.00 |
| Duration of ePBG required (Months). | 5 |

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

PRINCIPAL CONTROLLER OF ACCOUNTS (FYS)

PSD must be drawn in favour of PCA (Fys.), Kolkata. The PSD submitted in form of FDR / BG should be addressed to PCA (Fys.), Kolkata, as per details mentioned below: a) Name of the Account Holder: PCA (Fys.) Calcutta b) Name of Bank: State Bank of India c) Bank Address: 1, Strand Road, Samridhi Bhavan, Kolkata - 01. d) A/C No.: 11143631545 e) IFCS Code: SBIN0014524 The Original copy of 'Performance Security Deposit (PSD), addressed to PCA (Fys.), Kolkata', is to be forwarded to O.F. Bhandara, only. (Principal Controller Of Accounts)

Splitting

Bid splitting not applied.

MII Purchase Preference

| MII Purchase Preference | Yes |
|-------------------------|-----|

MSE Purchase Preference

| MSE Purchase Preference | Yes |
|-------------------------|-----|

- 1. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.
- 2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total OHANTITY
- 3. Short Duration Bid has been published by the Buyer with the approval of the Competent authority due to Emergency procurement of critical products/services.

Power Cable For Direct Burial XIpe Ugac Cable-IS: 10418 (1000 meter)

(Minimum 50% Local content required for MII compliance)

| Brand Type | Registered Brand |
|------------|------------------|
| 1 | <u> </u> |

Technical Specifications

* As per GeM Category Specification

| Specification | Specification Name | Bid Requirement (Allowed Values) | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| GENERIC | Size of Cable (in Sq.mm) | 240.0 | | |
| | Number of cores (nos) | 3.5, 4 | | |
| | Cable Type | Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005 | | |
| | Armouring | Galvanised steel Strip armoured | | |
| | Armouring Type | single wire or strip armouring | | |
| | shape of conductor | Stranded and Shaped | | |
| CONSTRUCTIONAL | Material of conductor | Aluminium EC Grade | | |
| | standard cable length on a drum | 1000 meter | | |
| CERTIFICATIONS Availability of Type test report from Central government/NABL/ILAC accridiated laboratory to prove conformity to the specification for minimum and maximum ratings. | | yes | | |

Additional Specification Parameters - Power Cable For Direct Burial XIpe Ugac Cable-IS: 10418 (1000 meter)

| Specification Parameter Name | Bid Requirement (Allowed Values) | |
|---------------------------------|----------------------------------|--|
| Armouring Type | Strip Armouring | |

^{*} Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

| S.No. | Consignee/Reporti ng Officer | Address | Quantity | Delivery Days |
|-------|---------------------------------|----------------|----------|---------------|
| 1 | ***** | ******BHANDARA | 1000 | 90 |

Special terms and conditions-Version:1 effective from 04-05-2020 for category Power Cable For Direct Burial XIpe Ugac Cable-IS: 10418

Specification for Cross linked Polyethylene insulated thermoplastic sheathed cables" is as per IS:7098 (Part 1):1988 with latest amendments including amendment no.5. Manufacturer shall furnish calculation sheet as per Appendix-C of IS:7098 (Part 1):1988 amdt., no.5 to buyer/consignee on demand. (Gem Category: Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with latest amendment including amendment no.5)

Buyer Added Bid Specific Additional Terms and Conditions

- 1. Scope of supply (Bid price to include all cost components): Only supply of Goods
- 2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.
- 3. Purchase Preference linked with Local Content (PP-LC) Policy:

The bid clause regarding "Preference to Make In India products" stands modified in this bid and shall be governed by the PPLC Policy No. FP-20013/2/2017-FP-PNG dated 17.11.2020 issued by MoP&NG as amended up to date. Accordingly, bidders with Local Content less than or equal to 20% will be treated as "Non Local Supplier". The prescribed LC shall be applicable on the date of Bid opening. Sanctions on the bidders for false / wrong declaration or not fulfilling the Local Content requirement shall be as per the PPLC policy. Further following additional provisions are added in the certification and verification of local content provision of the Preference to Make in India clause:

- i. In case of foreign bidder, certificate from the statutory auditor or cost auditor of their own office or subsidiary in India giving the percentage of local content is also acceptable. In case office or subsidiary in India does not exist or Indian office/subsidiary is not required to appoint statutory auditor or cost auditor, certificate from practicing cost accountant or practicing chartered accountant giving the percentage of local content is also acceptable.
- ii. Along with Each Invoice: The local content certificate (issued by statutory auditor on behalf of procuring company) shall be submitted along with each invoice raised. However, the % of local content may vary with each invoice while maintaining the overall % of local content for the total work/purchase of the pro-rata local content requirement. In case, it is not satisfied cumulatively in the invoices raised up to that stage, the supplier shall indicate how the local content requirement would be met in the subsequent stages.
- iii. The bidder shall submit an undertaking from the authorized signatory of bidder having the Power of Attorney along with the bid stating the bidder meets the mandatory minimum LC requirement and such undertaking shall become a part of the contract.
- 4. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
- 5. Buyer uploaded ATC document Click here to view the file.
- 6. Buyer Added text based ATC clauses

(I) SELLER SHOULD UPLOAD THE BID SECURITY DECLARATION FORMAT DULY COMPLETED IN ALL RESPECT.

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the

4/5

Disclaimer

bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

This Bid is also governed by the General Terms and Conditions

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---