

Bid Document

Bid Details	
Bid End Date/Time	11-08-2021 09:00:00
Bid Opening Date/Time	11-08-2021 09:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Oil India Limited
Organisation Name	Oil India Limited
Office Name	Oil India Limited
Total Quantity	7
Item Category	Potable water purification system Reverse Osmosis or UV based
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Time allowed for Technical Clarifications during technical evaluation	7 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Estimated Bid Value	225000
Evaluation Method	Total value wise evaluation

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MII Purchase Preference

MI Purchase Preference	No
------------------------	----

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 100%(selected by Buyer) percentage of total QUANTITY.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Potable Water Purification System Reverse Osmosis Or UV Based (7 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
Standards	Certification for the product	CE
	Manufacturers Quality System Certifications	ISO 9001:2015
	Manufacturers Environment Management System Certifications	ISO 14001:2004
	Manufacturers Health and Safety Management System Certifications	ISO 18001:2007
Performance Parameters	Maximum Input Water TDS allowed to the system	2000

Specification	Specification Name	Bid Requirement (Allowed Values)
	Type of water purification technology	RO +UV
	Operation	Fully automatic with auto cut off
	Ultraviolet (UV) LAMP	Yes
	Conformity to Standard for Ultraviolet system	IS 14724 (latest) for water purification system with Ultraviolet disinfection
	Recovery at 27 degree Centigrade	70-80
	Filtration Capacity in liter/ hour	25
	Provision of Arsenic removal	No
	Provision of Floride removal	Yes
	Provision of Chloride removal	Yes
	Alkaline filter	Yes
	Storage tank	Inbuilt
	Type of out put water Storage Tank	Stainless Steel
	Storage Tank Capacity (storage tank external for higher capacity if required to be arranged by buyer)	25ltr
	Minimum inlet pressure	0.3 KG/CM2
	Maximum inlet temperature	35 DEGREE
	Digital display	No
	Real time TDS display	No
	Real time pH Display	Yes
	High pressure pump	Yes
	Raw water/Chemical Raw water/Chemical Cleaning PUMP	Yes
	Micron Filter	Yes
	Total Dissolved Solids Removal Percentage from RO Membrane	90%
	Particulate Filter Porosity	10 Micro
	Pressure vessel Sand Filter	No
	Pressure vessel carbon Filter	Yes
	Pressure Vessel Dual Media Filter	No

Specification	Specification Name	Bid Requirement (Allowed Values)
	Membrane Housing	Yes
	Body of filter	ABS Food grade
	Auto cut	Yes
	Number of candles	2
	Power supply	230 Volt single phase
	Installation Type	Wall mounted, Under sink, Floor Mounted, Floor Mounted and Enclosed
Miscellaneous Parameters	Warranty in years including replacement of filters Sediment & carbon twice a year)	1
	Warranty in years free replacement of machine	1
	Antiscalant- where silica is up to 10 ppm/where Mica is up to 100 ppm	Yes
	Availability of type test Test REPORT for Filtering Size of micron Particles	Yes
	Availability of test report from Govt/NABL/ilac Lab (Design Evaluation Report as per IS:14724	Yes
	Availability of toll free centers for customer support	Yes
	Installation and Commissioning inclusive in the scope of Supply*	Yes
	Availability of NABL Accredited Laboratory Facility with OEM	Yes
	Inlet Pipe & Fitting from raw water sources to water purification system	to be arranged by buyer/consignee
	Pipe & Fitting from Out let to purified water tank	To be arranged by buyer /consignee

Additional Specification Parameters - Potable Water Purification System Reverse Osmosis Or UV

Based (7 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Installation type of the Filter shall be	Wall mounted Type. Bidder must confirm the same in their offer.
Bidder shall confirm in their offer	Installation and after sale services shall be provided by the bidder on placement of order. Certificate of Warranty shall be provided along with the supply of materials.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	DIPANKAR PATHAK	786602,Oil India Limited, Duliajan, Assam	7	120

Buyer Added Bid Specific Additional Terms and Conditions

1. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
2. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions.](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---

